



COUNTY OF DUTCHESS
DEPARTMENT OF BEHAVIORAL AND COMMUNITY HEALTH
DIVISION OF ENVIRONMENTAL HEALTH SERVICES

NOTIFICATION OF APPROVAL

March 27, 2019

Linda French, Supervisor
Town of Dover
126 E Duncan Hill Road
Dover Plains, New York 12522

Re: Dover Library Public Water System Modifications (Federal ID 1330755)
Tax Map No. 04-7160-03-031126
Pleasant Ridge Road in the Town of Dover

Dear Ms. French,

The plan and engineer's report for the above referenced project were approved on March 27, 2019 as meeting the appropriate and applied technical standards, guidelines, policies and procedures for adding a filter, meter, ultraviolet light disinfection and other appurtenances to the existing public water system serving the town library and American Legion Hall.

This approval has been granted on the following conditions.

- 1. The non-community public water system modifications shall be installed in complete conformity to the approved plan and report.**
- 2. The water system modifications shall be installed in a manner that allows for a safe and adequate potable water supply at all times.**


This approval is not to be construed in any way as an authorization to operate. Authorization to operate will be granted only after a Certification of Construction Compliance and testing results are received from a licensed New York State Professional Engineer (NYSPE). The engineering section of this Department requires notification of construction commencement so that, at its option, an inspection can be made. When all these conditions are complied with, authorization to operate may be requested.

Dover Library PWS Modifications
March 27, 2019
Page 2

Approval of the plan and engineer's report shall terminate and thereafter be null and void unless construction is undertaken within five (5) years from the date of approval. Re-submission or revised submission of plans and/or associated documents shall be subject to compliance with the technical standards, guidelines, policies and procedures in effect at the time of re-submission.

The approved plan and engineer's report have been given to your engineer, Joseph Berger, P.E.

Very truly yours,



David MacDougall
Public Health Engineer
Environmental Health Services

cc: Joseph P. Berger, P.E. (w/plan and report)
Town of Dover Bldg. Inspector
DWEF (w/plan and report).
File (103837) (w/plan and report)