



Stephen Tomasik
Project Manager
Energy Projects and Management
Division of Environmental Permits
NYS Department of Environmental Conservation
625 Broadway - 4th Floor
Albany, New York 12233-1750

Steven Riva
Chief, Permitting Section
Air Programs Branch
United States Environmental Protection Agency
Region 2
290 Broadway
New York, NY 10007-1866

Subject:

Additional Information to Supplement PSD Air Permit Application and State Air Facility Permit Application (#3-1326-00275/00004)

Dear Mr. Tomasik and Mr. Riva:

On November 15, 2010, a letter was sent to the New York State Department of Conservation (NYSDEC) and United States Environmental Protection Agency (USEPA) responding to comments on the Prevention of Significant Deterioration (PSD) Air Permit Application and State Facility Air Permit Application (Air Permit Application) for the proposed Cricket Valley Energy Center (CVE). Comments were provided by NYSDEC and USEPA via the following correspondence:

- Letter from Steven C. Riva (USEPA) to Frederick Sellars, May 5, 2010
- Letter from Margaret Valis (NYSDEC) to Frederick Sellars, June 15, 2010
- Letter from Jeffrey Lawyer (NYSDEC) to Frederick Sellars, August 3, 2010

Most of the comments were fully addressed in the response letter. However, in our response letter, we also indicated that we would update the PSD Air Permit Application and the State Facility Permit Application with additional information including turbine vendor specifications, cumulative modeling for nitrogen dioxide

ARCADIS U.S., Inc.
2 Executive Drive
Suite 303
Chelmsford
Massachusetts 01824
Tel 978.937.9999
Fax 978.937.7555
www.arcadis-us.com

Date:
February 4, 2010

Contact:
Frederick.Sellars

Phone:
978-937-9999 ext. 317

Email:
Frederick.Sellars@
arcadis-us.com

Our ref:
CO001447.0003.00004

(NO₂), and updated state air permit forms. This package provides the information to supplement, and in some cases supplant, information provided in the Air Permit Application for CVE. In a conversation with Jeffrey Lawyer on January 4, 2011, he agreed that he would accept an updated version of the air resources section of the Draft Environmental Impact Statement (DEIS), rather than updated pages of the Air Permit Application. An updated version of the DEIS has been electronically submitted to Stephen Tomasik at NYSDEC on February 4, 2011 as a separate submittal. However, a copy of the updated section is also provided as Attachment 1 with this letter. There is additional updated information associated with the Air Permit Application, such as state air permit forms, that are not included in the air section of the DEIS. This updated information is also provided with this letter as described below

Revisions to Section 4.0 of the DEIS

A pre-review draft of Section 4.0 of the DEIS (Air Resources), with associated appendices, was originally submitted to Stephen Tomasik for NYSDEC review on October 22, 2010. Many of the agency comments referenced above had been addressed in this version. However, since that time, the DEIS section has been updated to reflect minor changes to project emissions, other text additions, remaining regulatory comments and a new regulatory requirement for a greenhouse Gas (GHG) Best Available Control Technology (BACT) analysis. Also, as indicated in our agency response letter, Section 4.0 of the DEIS has been updated to include cumulative modeling demonstrating compliance with the 1-hour nitrogen dioxide (NO₂) National Ambient Air Quality Standard (NAAQS).

Text and Emissions Updates

The project-related emissions and other DEIS text has been updated to accommodate additional changes to the project design. Specifically, the following changes have been made:

- Final selection of a combustion turbine vendor and model number, General Electric 7FA.05;
- Minor changes to start-up and shutdown emissions;
- Addition of a fourth black start generator;
- Addition of a minimum combustion turbine load case at 36 percent;
- Minor changes to tables updating the NAAQS for 1-hour NO₂, lead and 1-hour Sulfur Dioxide (SO₂), and;

- Inclusion of 1-hour SO₂ in the air quality modeling analysis.

1-hour NO₂ Cumulative Modeling

In response to a comment from USEPA, a cumulative modeling analysis has been conducted for 1-hour NO₂. With the assistance of the USEPA, NO₂ interactive modeling runs for CVE were made with the BETA version of AERMOD, B10363. The results demonstrate clearly that the CVE project does not contribute significantly to any predicted NAAQS violations.

Model runs to demonstrate compliance were performed in the following manner:

- 1) AERMOD was run for the CVE project (worst-case scenario) to identify receptors with predicted impacts above Significant Impact Levels (SILs).
- 2) Interactive model runs were performed for the full modeling domain, including all 692 receptors where CVE has predicted impacts above the 1-hour NO₂ SIL.
- 3) Receptors with predicted impacts above the NAAQS of 188 µg/m³ were identified. Of the 692 receptors where the CVE project showed SIL exceedances for any hour modeled predicted 5-yr 98th percentile concentrations at 681 receptors were below 185 µg/m³. Five receptors had 5-year average predicted 8th highest daily maximum 1-hour concentrations, including background that exceeded the NAAQS. The highest predicted 98th percentile value at any of these receptors was 214 µg/m³. Another six receptors had predicted 5-yr 98th percentile concentrations below 188 µg/m³, but above 185 µg/m³, for a total of 11 receptors.
- 4) For those 11 receptors, predicted impacts were evaluated with and without the CVE emission sources. Predicted concentrations were compared for all days with at least one maximum 1-hour concentration exceeding the NAAQS, using MAXDAILY output tables. Between 33 and 87 exceedances were predicted at each of the 11 receptors, for a total of 499 exceedance-days.
- 5) For those 499 exceedance-days, the largest difference in the predicted daily maximum 1-hr NO₂ concentration at any receptor, with and without CVE's contribution, is 0.17 µg/m³, far below the interim SIL of 7.5 µg/m³.

This analysis demonstrates that none of the predicted 499 maximum daily 1-hour concentrations above the NAAQS at any of these 11 receptors involved a significant contribution from the CVE project. Thus, the project will not contribute significantly to any predicted violation of the 1-hour NAAQS.

GHG BACT Analysis

On April 2, 2007, the Supreme Court found that GHGs, including carbon dioxide, are air pollutants covered by the Clean Air Act (CAA). On May 13, 2010, the USEPA issued a final rule (called the "Tailoring Rule") that establishes an approach to greenhouse gas emissions from stationary sources under the CAA. This final rule "tailors" the requirements of the CAA permitting program to limit which facilities will be required to obtain PSD permits. The CAA permitting program emissions thresholds for criteria pollutants are 100 tons per year or 250 tons per year. While these thresholds are appropriate for criteria pollutants, they are not feasible for GHG emissions as they are emitted in much greater quantities.

Beginning January 2, 2011, sources subject to the PSD program (i.e., new major sources such as CVE) are subject to permitting requirements for their GHG emissions under PSD. For these projects, those with GHG emission increases of 75,000 tpy or greater are required to determine BACT for their GHG emissions.

NYSDEC adopted amendments to their regulations on December 29, 2010 to include the provisions of the Tailoring Rule as described above.

CVE has triggered major source thresholds of pollutants other than GHGs. In addition, potential emissions of GHGs from the project exceed the 75,000 tpy threshold described above. As such, PSD review is required for GHG emissions, including a BACT analysis. The DEIS (section attached) has been updated to include a BACT analysis for GHGs.

Updated Air Permit Application Forms

NYSDEC air permit application forms have been updated in response to comments from Jeffrey Lawyer. The updated forms are provided as Attachment 2 with this package. The forms have been marked to indicate which pages have updated information. Specifically the following changes have been made:

- The black start emergency generators and fire pump have been identified as emission sources and processes/emission points for these sources have been defined;
- Unique processes have been defined for each combustion turbine, and natural gas has not been repeated as a process within the same emission source, and;

- Equipment information such as turbine manufacturer, model number, exhaust flow rate and other parameters have been updated to reflect the final choice in turbine vendor.

Additional Information for Air Permit Application

As mentioned previously, the Air Permit Application provided additional supporting documentation that was not included in the Air Resources section of the DEIS. The additional attached information is summarized below:

- Vendor information for fire pump, black start generators and auxiliary boiler
- Supporting Calculations for Modeling Results (provided on diskette)
 - Steady state
 - Startup/Shutdown plus auxiliary boiler
 - Auxiliary Boiler
 - Black Start Generator
 - Fire Pump
- Supporting Figures for Modeling Results
 - Land use Figures for AERSURFACE
 - 1-hour Carbon Monoxide (CO)
 - 8-hour CO
 - 1-hour NO₂
 - Annual NO₂
 - 24-hour Particulate Matter less than 2.5 microns (PM_{2.5})
 - Annual PM_{2.5}
 - 24-hour Particulate Matter less than 10 microns (PM₁₀)
 - 1-hour SO₂
 - 3-hour SO₂
 - 24-hour SO₂
 - Annual SO₂
- Computer Diskette with Modeling Files for 1-hour NO₂ cumulative modeling.

If you have any questions or comments regarding this supplemental information, please do not hesitate to contact me at 978-937-9999 ext 317 or frederick.sellars@arcadis-us.com. Thank you for your review of the CVE Air Permit Application. We look forward to continuing to work with you on this important project.

Sincerely,

ARCADIS U.S., Inc.



Frederick M. Sellars
Vice President

Copies:

M. Valis, NYSDEC
J. Lawyer, NYSDEC
J. Aherns, CVE

ATTACHMENT 1

Redacted - See DEIS Section 4 for most recent
version of the Air Resources Section

ARCADIS

ATTACHMENT 2

**New York State Department of Environmental Conservation
Air Permit Application**

ORIGINAL 

DEC ID									
-									

APPLICATION ID														
-														

OFFICE USE ONLY									

Section I - Certification

Title V Certification	
I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons directly responsible for gathering the information (required pursuant to 6 NYCRR 201-6.3(d)) I believe the information is, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.	
Responsible Official	Title
Signature	Date <u> / / </u>

State Facility Certification	
I certify that this facility will be operated in conformance with all provisions of existing regulations.	
Responsible Official <u>Thomas E Spang</u>	Title <u>President</u>
Signature <u>[Signature]</u>	Date <u>3/8/10</u>

Section II - Identification Information

<input type="checkbox"/> Title V Facility Permit <input type="checkbox"/> New <input type="checkbox"/> Significant Modification <input type="checkbox"/> Renewal <input type="checkbox"/> Minor Modification	<input type="checkbox"/> Administrative Amendment General Permit Title: _____	<input checked="" type="checkbox"/> State Facility Permit <input checked="" type="checkbox"/> New <input type="checkbox"/> Modification General Permit Title: _____
<input checked="" type="checkbox"/> Application involves construction of new facility		<input type="checkbox"/> Application involves construction of new emission unit(s)

Owner/Firm				
Name <u>Cricket Valley Energy Center, LLC</u>				
Street Address <u>31 Milk St, Suite 1001</u>				
City <u>Boston</u>	State <u>MA</u>	Country	Zip <u>02109</u>	
Owner Classification <input type="checkbox"/> Federal	<input type="checkbox"/> State	<input type="checkbox"/> Municipal		Taxpayer ID
<input checked="" type="checkbox"/> Corporation/Partnership	<input type="checkbox"/> Individual			<u>270605498</u>
Facility				
Name <u>Cricket Valley Energy</u>				
Location Address <u>2241 NY Route 22</u>				
<input type="checkbox"/> City / <input checked="" type="checkbox"/> Town / <input type="checkbox"/> Village <u>Dover</u>			Zip <u>12522</u>	
Project Description				
<input checked="" type="checkbox"/> Continuation Sheet(s) This application is for a new approximately 1,000 megawatt (MW) combined cycle electric generating facility, firing natural gas as the sole fuel of the combustion turbines, auxiliary boiler and heat recovery steam generator.				

Owner/Firm Contact Mailing Address			
Name (Last, First, Middle Initial) <u>Sellers, Frederick M.</u>		Phone No. <u>(978) 937-9999 x317</u>	
Affiliation <u>Arcadis, Permitting Consultant</u>		Title <u>Vice President</u>	
Street Address <u>2 Executive Drive, Suite 303</u>		Fax No. <u>(978) 937-7555</u>	
City <u>Chelmsford</u>	State <u>MA</u>	Country	Zip <u>01824</u>
Facility Contact Mailing Address			
Name (Last, First, Middle Initial) <u>De Meyere, Robert E.</u>		Phone No. <u>(617) 456-2214</u>	
Affiliation <u>Cricket Valley Energy Center, LLC</u>		Title <u>Director, Development</u>	
Street Address <u>31 Milk St, Suite 1001</u>		Fax No. <u>(617) 456-2201</u>	
City <u>Boston</u>	State <u>MA</u>	Country	Zip <u>02109</u>

DEC ID									
-									

Section II - Identification Information

Project Description (continuation)

The project is comprised of three combined cycle units. Each unit consists of one F-Class Technology combustion turbine generator (CTG), one heat recovery steam generator (HRSG) with supplemental natural gas duct firing, one steam turbine generator (STG), and an associated air cooled condenser (ACC). The project is intended to operate as a base load facility and is proposing to operate 8,760 hours per year, incorporating a range of load conditions. In addition to the combustion turbines, the facility will contain ancillary combustion equipment including one natural gas fired auxiliary boiler, one diesel fired fire pump engine and four diesel fired black-start generators.

A detailed description of the proposed project is provided in Section 2.0 of the document.

DEC ID									
-									

Section III - Facility Information

Classification					
<input type="checkbox"/> Hospital	<input type="checkbox"/> Residential	<input type="checkbox"/> Educational/Institutional	<input type="checkbox"/> Commercial	<input type="checkbox"/> Industrial	<input checked="" type="checkbox"/> Utility

Affected States (Title V Only)					
<input type="checkbox"/> Vermont	<input type="checkbox"/> Massachusetts	<input type="checkbox"/> Rhode Island	<input type="checkbox"/> Pennsylvania	Tribal Land: _____	
<input type="checkbox"/> New Hampshire	<input type="checkbox"/> Connecticut	<input type="checkbox"/> New Jersey	<input type="checkbox"/> Ohio	Tribal Land: _____	

SIC Codes											
4911											

Facility Description		<input checked="" type="checkbox"/> Continuation Sheet(s)
The facility will consist of three combined cycle units. Each unit will fire natural gas exclusively and consist of one F-Class combustion turbine generator (CTG), a heat recovery steam generator (HRSG) with supplemental duct firing, and an associated...		

Compliance Statements (Title V Only)	
<p>I certify that as of the date of this application the facility is in compliance with all applicable requirements: <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p>If one or more emission units at the facility are not in compliance with all applicable requirements at the time of signing this application (the 'NO' box must be checked), the noncomplying units must be identified in the "Compliance Plan" block on page 8 of this form along with the compliance plan information required. For all emission units at this facility that are operating <u>in compliance</u> with all applicable requirements complete the following:</p> <ul style="list-style-type: none"> " This facility will continue to be operated and maintained in such a manner as to assure compliance for the duration of the permit, except those units referenced in the compliance plan portion of Section IV of this application. " For all emission units, subject to any applicable requirements that will become effective during the term of the permit, this facility will meet all such requirements on a timely basis. " Compliance certification reports will be submitted at least once a year. Each report will certify compliance status with respect to each requirement, and the method used to determine the status. 	

Facility Applicable Federal Requirements									<input checked="" type="checkbox"/> Continuation Sheet(s)
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	201	1						
6	NYCRR	201	2						
6	NYCRR	201	3	2					
6	NYCRR	201	3	3					

Facility State Only Requirements									<input type="checkbox"/> Continuation Sheet(s)
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	202	2						
6	NYCRR	207	2						
6	NYCRR	221	2						
6	NYCRR	272	2						

DEC ID									
-									

Section III - Facility Information (continued)

Facility Compliance Certification								☒ Continuation Sheet(s)	
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	211	3						
☒ Applicable Federal Requirement		" Capping		CAS No.		Contaminant Name			
" State Only Requirement				-		Opacity			
Monitoring Information									
☒ Ambient Air Monitoring		" Work Practice Involving Specific Operations				" Record Keeping/Maintenance Procedures			
Description									
No person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.									
As a natural gas fired facility, opacity from the equipment will not exceed these limits. Compliance with this requirement will be demonstrated via visual inspection in accordance with 40 CFR Part 60, Method 9.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
						40 CFR 60, Method 9			
		Parameter				Manufacturer Name/Model No.			
Code		Description							
01		Opacity							
Limit			Limit Units						
Upper		Lower		Code	Description				
20		0		136	Percent				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
18	6-minute avg (Method 9)		4	As required.		10	Upon request.		

Facility Emissions Summary					☒ Continuation Sheet(s)
CAS No.	Contaminant Name	PTE		Actual (lbs/yr)	
		(lbs/yr)	Range Code		
NY075 - 00 - 5	PM-10		G		
NY075 - 00 - 0	PARTICULATES		G		
7446 - 09 - 5	SULFUR DIOXIDE		F		
NY210 - 00 - 0	OXIDES OF NITROGEN		H		
630 - 08 - 0	CARBON MONOXIDE		H		
7439 - 92 - 1	LEAD		A		
NY998 - 00 - 0	VOC		G		
NY100 - 00 - 0	HAP		C		
7664- 93 - 9	SULFURIC ACID MIST		C		
106 - 99 - 0	1,3 -Butadiene		Y		
75 - 07 - 0	Acetaldehyde		Y		
107 - 02 - 8	Acrolein		Y		
120 - 12 - 7	Anthracene		Y		

DEC ID									
-									

Section III - Facility Information

Facility Emissions Summary (continuation)				
CAS No.	Contaminant Name	PTE		Actual (lbs/yr)
		(lbs/yr)	Range Code	
7664 - 41 - 7	Ammonia		G	
71 - 43 - 2	Benzene		Y	
56 - 55 - 3	Benzo(a)anthracene		Y	
50 - 32 - 8	Benzo(a)pyrene		Y	
106 - 97 - 8	Butane		C	
218 - 01 - 9	Chrysene		A	
53 - 70 - 3	Dibenz(a,h)anthracene		A	
74 - 84 - 0	Ethane		D	
100 - 41 - 4	Ethylbenzene		Y	
50 - 00 - 0	Formaldehyde		Y	
110 - 54 - 3	Hexane		Y	
91 - 20 - 3	Napthalene		Y	
109 - 66 - 0	Pentane		C	
85 - 01 - 8	Phenanthrene		A	
130498 - 29 - 2	PAH		Y	
74 - 98 - 6	Propane		C	
115 - 07 - 1	Propylene		A	
75 - 56 - 9	Propylene Oxide		Y	
129 - 00 - 0	Pyrene		A	
108 - 88 - 3	Toluene		Y	
133 - 02 - 7	Xylene (Total)		Y	
07440 - 38 - 2	Arsenic		Y	
07440 - 39 - 3	Barium		A	
07740 - 41 - 7	Beryllium		Y	
07740 - 43 - 9	Cadmium		Y	
07740 - 47 - 3	Chromium		Y	
07740 - 48 - 4	Cobalt		Y	
07740 - 50 - 8	Copper		A	
07439 - 96 - 5	Manganese		Y	
07439 - 97 - 6	Mercury		Y	
07439 - 98 - 7	Molybdenum		A	
07440 - 02 - 0	Nickel		Y	
07782 - 49 - 2	Selenium		Y	
07440 - 62 - 2	Vanadium		A	
07440 - 66 - 6	Zinc		A	
-	-			
-	-			

DEC ID									
-									

Section III - Facility Information

Facility Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	225	3						
☒ Applicable Federal Requirement ☐ State Only Requirement		" Capping	CAS No.			Contaminant Name			
			7704-34-9			Sulfur			
Monitoring Information									
☐ Ambient Air Monitoring		☐ Work Practice Involving Specific Operations			☒ Record Keeping/Maintenance Procedures				
Description									
The combustion turbines at the facility will only utilize natural gas. Ancillary equipment at the facility will only utilize ULSD fuel. The ULSD will have a sulfur content no greater than 0.0015% sulfur by weight. The sulfur content of the fuel will be certified by the vendor and monitored by the facility.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Parameter of process material							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit			Limit Units						
Upper		Lower	Code	Description					
0.0015			57	Percent by weight.					
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum - not to be exceeded		11	Per delivery		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
☐ Applicable Federal Requirement ☐ State Only Requirement		" Capping	CAS No.			Contaminant Name			
			- -						
Monitoring Information									
☐ Ambient Air Monitoring		☐ Work Practice Involving Specific Operations			☐ Record Keeping/Maintenance Procedures				
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit			Limit Units						
Upper		Lower	Code	Description					
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		

New York State Department of Environmental Conservation
Air Permit Application

MODIFIED 

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Description										" Continuation Sheet(s)
EMISSION UNIT	U	-	0	0	0	0	0	1	This generating unit will fire natural gas exclusively and consist of one CTG, one HRSG with supplemental duct firing, and an associated ACC. The auxiliary boiler and black start generators will also exhaust through this stack.	

Building					" Continuation Sheet(s)
Building	Building Name		Length (ft)	Width (ft)	Orientation
CTGEN01	Turbine Generation Building		670	100	0°
HRSG01	Heat Recovery Steam Generator Enclosure		128	160	90°
ACC01	Air Cooled Condenser		190	190	90°

Emission Point							" Continuation Sheet(s)
EMISSION PT.	E	P	0	0	1	No. 1 Combustion Turbine/HRSG, Auxiliary Boiler, 4 Black Start Generators	
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
435	283	170	228	179	N/A	N/A	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
70.2	1,193,469					N/A	
EMISSION PT.							
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control							" Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.
ID	Type				Code	Description	
CT001	C	12/2011	3/2015	N/A			General Electric 7FA.05
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
2061	25	MMBtu/hr, HHV@ ISO conditions					
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.
ID	Type				Code	Description	
DB001	C	12/2011	3/2015	N/A			TBD
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
379	25	MMBtu/hr, HHV@ ISO conditions					

DEC ID									
-									

Section IV - Emission Unit Information

EMISSION UNIT									
U	-	0	0	0	0	1	Emission Source/Control (continuation)		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
DLN01	K	12/2011	3/2015	N/A	103	Dry low NOx Burner	General Electric		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
SCR01		12/2011	3/2015	N/A	033	Selective Catalytic Reduction	TBD		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
oxc01		12/2011	3/2015	N/A	110	Catalytic oxidation	TBD		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
AUX01	C	12/2011	3/2015	N/A	102		TBD		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
60	25	mmBtu/hr, HHV							
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
LNB01	K	12/2011	3/2015	N/A	102	Low NOx Burner	TBD		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
FGR01	K	12/2011	3/2015	N/A	026	Flue Gas Recirculation	TBD		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
BSG01	C	12/2011	3/2015	N/A			Caterpillar		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
3	216	Megawatt							



DEC ID									
-									

Section IV - Emission Unit Information

EMISSION UNIT									
U	-	0	0	0	0	1	Emission Source/Control (continuation)		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
BSG02	C	12/2011	3/2015	N/A			Caterpillar		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
3	216	Megawatt							
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
BSG03	C	12/2011	3/2015	N/A			Caterpillar		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
3	216	Megawatt							
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
BSG04	C	12/2011	3/2015	N/A			Caterpillar		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
3	216	Megawatt							
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Process Information										* Continuation Sheet(s)										
EMISSION UNIT							U	-	0	0	0	0	1	PROCESS		P	0	1		
Description																				
Process P01 represents natural gas firing in the Unit #1 F-class combustion turbine with and without supplemental duct firing. Dry low-NOx combustion technology and selective catalytic reduction will be used to control emissions of NOx from the process. An oxidation catalyst will be used to control emissions of CO and VOC. The natural gas HHV is assumed to be 966 Btu per standard cubic foot. Please see Section 2.0 of the application for a more detailed process description.																				
Source Classification Code (SCC)			Total Thruput				Thruput Quantity Units													
			Quantity/Hr		Quantity/Yr		Code		Description											
2-01-002-01			2.76		24,135		0115		million cubic feet of natural gas											
" Confidential * Operating at Maximum Capacity " Activity with Insignificant Emissions			Operating Schedule				Building		Floor/Location											
			Hrs/Day		Days/Yr															
			24		365															
Emission Source/Control Identifier(s)																				
CT001		DLN01		SCR01		OXC01		DB001												
EMISSION UNIT							-							PROCESS						
Description																				
Source Classification Code (SCC)			Total Thruput				Thruput Quantity Units													
			Quantity/Hr		Quantity/Yr		Code		Description											
" Confidential " Operating at Maximum Capacity " Activity with Insignificant Emissions			Operating Schedule				Building		Floor/Location											
			Hrs/Day		Days/Yr															
Emission Source/Control Identifier(s)																				

New York State Department of Environmental Conservation
Air Permit Application

MODIFIED 

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements								" Continuation Sheet(s)	
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4320					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4330	a				
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4333	a				
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4340	b				

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements								" Continuation Sheet(s)	
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U-00001	EP001	P01	CT001	6	NYCRR	242	1	6					
U-00001	EP001	P01	CT001	6	NYCRR	242	1	7					
U-00001	EP001	P01	CT001	6	NYCRR	242	2						
U-00001	EP001	P01	CT001	6	NYCRR	242	3						

Emission Unit Compliance Certification										x Continuation Sheet(s)	
Rule Citation											
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause		
6	NYCRR	231	5	4							
x Applicable Federal Requirement				" State Only Requirement			" Capping				
Emission Unit	Emission Point	Process	Emission Source	CAS No.			Contaminant Name				
U-00001	EP001	P01		NY210 - 00 - 0			Oxides of nitrogen				
Monitoring Information											
x Continuous Emission Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate							
" Intermittent Emission Testing				" Work Practice Involving Specific Operations							
" Ambient Air Monitoring				" Record Keeping/Maintenance Procedures							
Description											
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (w/ and w/o duct burning) as LAER.											
This will be achieved through the application of DLN burners in combination with SCR. This limit applies at all load conditions except startup and shutdown. The facility will use CEMS to monitor NOx stack emissions.											
Work Practice		Process Material					Reference Test Method				
Type	Code	Description									
							40 CFR 60, Appendix A, Method 7E				
Parameter		Manufacturer Name/Model No.									
Code	Description										
23	Concentration						DLN from General Electric, SCR is TBD.				
Limit				Limit Units							
Upper	Lower	Code	Description								
2.0		275	parts per million by volume (dry, corrected to 15% O2)								
Averaging Method			Monitoring Frequency			Reporting Requirements					
Code	Description		Code	Description		Code	Description				
08	1-hour average		01	Continuous		07	Quarterly				

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4345	a,b,c,d,e				
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4350					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4365	a				
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4375	a				
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4380	b				
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4395					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4400					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4405					
U-00001	EP001	P01		6	NYCRR	227	2	4	e				
U-00001	EP001	P01		6	NYCRR	227	2	6	b				
U-00001	EP001	P01		6	NYCRR	243	1	6					
U-00001	EP001	P01		6	NYCRR	243	1	7					
U-00001	EP001	P01		6	NYCRR	243	2						
U-00001	EP001	P01		6	NYCRR	243	3						
U-00001	EP001	P01		6	NYCRR	243	4						
U-00001	EP001	P01		6	NYCRR	243	5						
U-00001	EP001	P01		6	NYCRR	243	6						
U-00001	EP001	P01		6	NYCRR	243	7						
U-00001	EP001	P01		6	NYCRR	243	8						
U-00001	EP001	P01		6	NYCRR	244	1	6					
U-00001	EP001	P01		6	NYCRR	244	1	7					
U-00001	EP001	P01		6	NYCRR	244	2						
U-00001	EP001	P01		6	NYCRR	244	3						
U-00001	EP001	P01		6	NYCRR	244	4						
U-00001	EP001	P01		6	NYCRR	244	5						
U-00001	EP001	P01		6	NYCRR	244	6						
U-00001	EP001	P01		6	NYCRR	244	7						
U-00001	EP001	P01		6	NYCRR	244	8						
U-00001	EP001	P01		6	NYCRR	245	1	6					
U-00001	EP001	P01		6	NYCRR	245	1	7					
U-00001	EP001	P01		6	NYCRR	245	2						
U-00001	EP001	P01		6	NYCRR	245	3						
U-00001	EP001	P01		6	NYCRR	245	4						
U-00001	EP001	P01		6	NYCRR	245	5						
U-00001	EP001	P01		6	NYCRR	245	6						
U-00001	EP001	P01		6	NYCRR	245	7						
U-00001	EP001	P01		6	NYCRR	245	8						
U-00001	EP001	P01		6	NYCRR	231	5	4					
U-00001	EP001	P01		6	NYCRR	231	7	6					
U-00001	EP001	P01		40	CFR	72	A	6	a	3			

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U- 00001	EP001	P01		40	CFR	72	A	9					
U- 00001	EP001	P01		40	CFR	75	A	2					
U- 00001	EP001	P01		40	CFR	75	B	10					
U- 00001	EP001	P01		40	CFR	75	B	11					
U- 00001	EP001	P01		40	CFR	75	B	12					
U- 00001	EP001	P01		40	CFR	75	B	13					
U- 00001	EP001	P01		40	CFR	75	C						
U- 00001	EP001	P01		40	CFR	75	D						
U- 00001	EP001	P01		40	CFR	75	F						
U- 00001	EP001	P01		40	CFR	75	G						
U- 00001	EP001	P02	AUX01	40	CFR	60	Dc	48c	a				
U- 00001	EP001	P02	AUX01	6	NYCRR	227	2	d					
U- 00001	EP001	P02	AUX01	6	NYCRR	231	5	4					
U- 00001	EP001	P02	AUX01	6	NYCRR	231	7	6					
U- 00001	EP001	P03	BSG01	40	CFR	60	IIII	4202					
U- 00001	EP001	P03	BSG01	40	CFR	60	IIII	4205					
U- 00001	EP001	P03	BSG01	40	CFR	60	IIII	4207					
U- 00001	EP001	P03	BSG01	40	CFR	60	IIII	4209	a				
U- 00001	EP001	P03	BSG02	40	CFR	60	IIII	4202					
U- 00001	EP001	P03	BSG02	40	CFR	60	IIII	4205					
U- 00001	EP001	P03	BSG02	40	CFR	60	IIII	4207					
U- 00001	EP001	P03	BSG02	40	CFR	60	IIII	4209	a				
U- 00001	EP001	P03	BSG03	40	CFR	60	IIII	4202					
U- 00001	EP001	P03	BSG03	40	CFR	60	IIII	4205					
U- 00001	EP001	P03	BSG03	40	CFR	60	IIII	4207					
U- 00001	EP001	P03	BSG03	40	CFR	60	IIII	4209	a				
U- 00001	EP001	P03	BSG04	40	CFR	60	IIII	4202					
U- 00001	EP001	P03	BSG04	40	CFR	60	IIII	4205					
U- 00001	EP001	P03	BSG04	40	CFR	60	IIII	4207					
U- 00001	EP001	P03	BSG04	40	CFR	60	IIII	4209	a				
U- 00001	EP001	P03	BSG01	6	NYCRR	231	5	4					
U- 00001	EP001	P03	BSG01	6	NYCRR	231	7	6					
U- 00001	EP001	P03	BSG02	6	NYCRR	231	5	4					
U- 00001	EP001	P03	BSG02	6	NYCRR	231	7	6					
U- 00001	EP001	P03	BSG03	6	NYCRR	231	5	4					
U- 00001	EP001	P03	BSG03	6	NYCRR	231	7	6					
U- 00001	EP001	P03	BSG04	6	NYCRR	231	5	4					
U- 00001	EP001	P03	BSG04	6	NYCRR	231	7	6					
-													
-													

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	227	2	4	e	2			
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P01		NY210- 00 - 0		Oxides of nitrogen			
Monitoring Information									
X Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (with and without duct burning) as LAER for the proposed project. Meeting the LAER limit will also satisfy the requirements of 6NYCRR 227 2.4 as LAER is more stringent than the limit under this regulation.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						40 CFR 60, Appendix A, Method 7E			
		Parameter				Manufacturer Name/Model No.			
Code	Description				Manufacturer Name/Model No.				
23	Concentration				DLN from General Electric, SCR is TBD				
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0		275	Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		01	Continuous		07	Quarterly		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	KKKK	4345	a,b,c,d,e				
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U- 00001	EP001	P01		NY210- 00 - 0		Oxides of nitrogen			
Monitoring Information									
X Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (with and without duct burning) as LAER for the proposed project. Meeting the LAER limit will also satisfy the requirements of 40 CFR 60 Subpart KKKK as LAER is more stringent than the limit under this regulation.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						40 CFR 60, Appendix A, Method 7E			
		Parameter				Manufacturer Name/Model No.			
Code	Description				Manufacturer Name/Model No.				
23	Concentration				DLN from General Electric, SCR is TBD				
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0			Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		01	Continuous		07	Quarterly		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	5	4					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P01		NY998 - 00 - 0		Volatile organic compounds			
Monitoring Information									
" Continuous Emission Monitoring ☒ Intermittent Emission Testing " Ambient Air Monitoring					" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures				
Description									
Facility will maintain a VOC emission limit of 1.0 ppmv at 15 percent O2 without duct burning and 2.0 ppmv with duct burning as LAER.									
These levels of emissions will be achieved via good combustion control and an oxidation catalyst. These emission limits apply									
at all load conditions except startup and shutdown. Stack testing will be used to demonstrate compliance with these limits.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 25A			
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit		Limit Units							
Upper	Lower	Code	Description						
1.0		275	Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				-					
Monitoring Information									
" Continuous Emission Monitoring ☒ Intermittent Emission Testing " Ambient Air Monitoring					" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures				
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit		Limit Units							
Upper	Lower	Code	Description						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P01		630 - 08 - 0		Carbon monoxide			
Monitoring Information									
X Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a CO emission limit of 2.0 ppmv at 15 percent O2 with and without duct burning as BACT for the proposed project. This level of emissions will be achieved via good combustion control and an oxidation catalyst. The facility will use CEMS to monitor CO stack emissions.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description	CO Catalyst is TBD							
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0		275	Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				
08	1-hour average	01	Continuous	07	Quarterly				
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P01		NY075 - 00 - 0		Particulates			
Monitoring Information									
" Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
X Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a PM10/PM2.5 emission limit of 0.005 lb/MMBtu without duct burning and 0.006 lb/MMBtu with duct burning as BACT for the proposed project. These levels of emissions will be achieved by combusting only commercially available, pipeline quality natural gas in the turbines and duct burner. The facility will demonstrate compliance with these limits via stack testing.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				EPA RM5, 201/201A & 202			
Parameter		Manufacturer Name/Model No.							
Code	Description	CO Catalyst is TBD							
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.006		7	pounds per million Btus						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				
08	1-hour average	14	As required	10	Upon request				

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				-					
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit				Limit Units					
Upper		Lower		Code	Description				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P01		7446 - 09 - 5		Sulfur dioxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate X Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by combusting commercially available, pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF in the combustion turbines.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	12	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.5				13	grains per 100 DSCF				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum, not to be exceeded		14	As required		10	Upon request		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
x Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U - 00001	EP001	P01		7664 - 93 - 9		Sulfuric acid mist			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate x Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a sulfuric acid mist limit of 0.0004 lb/MMBtu without duct burning and 0.0006 with duct burning as BACT for the proposed project. These levels of emissions will be achieved by combusting commercially available, pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF in the combustion turbines.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.5				13	grains per 100 DSCF				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum, not to be exceeded		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				-					
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit				Limit Units					
Upper		Lower		Code	Description				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	2	5					
☒ Applicable Federal Requirement			☐ State Only Requirement			☐ Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U - 00001	EP001	P02	AUX01	NY210 - 00 - 0		Oxides of nitrogen			
Monitoring Information									
☐ Continuous Emission Monitoring ☐ Intermittent Emission Testing ☐ Ambient Air Monitoring				☐ Monitoring of Process or Control Device Parameters as Surrogate ☐ Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a NOx emission limit of 0.011 lb/MMBtu. The auxiliary boiler will use flue gas recirculation in combination with low-NOx burners. The facility will use vendor guarantees and/or stack testing to document compliance with this LAER emission limit, as required.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 7E			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.036		7	lbs per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	2	5					
☐ Applicable Federal Requirement			☐ State Only Requirement			☐ Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U - 00001	EP001	P02	AUX01	NY998 - 08 - 0		Volatile organic compounds			
Monitoring Information									
☐ Continuous Emission Monitoring ☐ Intermittent Emission Testing ☐ Ambient Air Monitoring				☐ Monitoring of Process or Control Device Parameters as Surrogate ☐ Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The facility will maintain a VOC emission limit of 0.0015 lb/MMBtu from the auxiliary boiler using good combustion practices in combination. This is considered to represent LAER. The facility will use vendor guarantees and/or stack testing to document compliance with this limit.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 25A			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.005		7	lbs per million Btus						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	As required		10	Upon request		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U - 00001	EP001	P02	AUX01	630 - 08 - 0		Carbon monoxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring					" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures				
Description									
The facility will maintain a CO emission limit of 0.0375 lb/MMBtu from the auxiliary boiler using good combustion practices. This limit represents BACT. The facility will use vendor guarantees and/or stack testing to document compliance with this limit.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.037		7	lbs per million Btus						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				
08	1-hour average	14	As required	10	Upon request.				
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U - 00001	EP001	P02	AUX01	NY075 - 00 - 0		Particulates			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring					" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures				
Description									
The project is proposing the exclusive use of clean-burning pipeline quality natural gas in conjunction with good combustion practices as BACT for the auxiliary boiler. The project will maintain a PM10/PM2.5 emission limit of 0.005 lb/MMBtu in the boiler using natural gas as the only fuel. The facility will use vendor emission guarantees and/or stack testing to ensure compliance with this limit as required.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				EPA RM5, 201/201A, 202			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.005		7	lbs per million Btus						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				
08	1-hr average	14	As required	10	Upon request				

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U- 00001	EP001	P02	AUX01	7664 - 09 - 05		Sulfur Dioxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate ☒ Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures						
Description									
The facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu as BACT for the proposed project. In order to maintain this limit, the proposed auxiliary boiler will only combust pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit			Limit Units						
Upper		Lower		Code	Description				
0.5				13	Grains per 100 DSCF				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U- 00001	EP001	P02	AUX01	7664 - 93 - 9		Sulfuric acid mist			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate ☒ Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures						
Description									
The facility will maintain an H2SO4 emission limit of 0.0001 lb/MMBtu as BACT for the proposed project. In order to maintain this limit, the proposed auxiliary boiler will only combust pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	12	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit			Limit Units						
Upper		Lower		Code	Description				
0.5				13	Grains per 100 DSCF				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	As required		10	Upon request		

New York State Department of Environmental Conservation
Air Permit Application



DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	IIII	4205					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P03	BSG01-04	NY210 - 00 - 0		Oxides of nitrogen			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The proposed engines will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a NOx + HC emission rate of 4.8 g/hp-hr. Compliance with these federal limits is also considered LAER. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit				Limit Units					
Upper		Lower		Code	Description				
4.8				319	Grams per brake horsepower hour				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
			14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	IIII	4205					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P03	BSG01-04	NY998 - 00 - 0		Volatile organic compounds			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The proposed engines will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a NOx + VOC emission rate of 4.8 g/hp-hr. Compliance with these federal limits is also considered LAER. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit				Limit Units					
Upper		Lower		Code	Description				
4.8				319	Grams per brake horsepower hour				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
			14	As required		10	Upon request		



DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	IIII	4205					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P03	BSG01-04	630 - 08 - 0		Carbon monoxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The proposed engines will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a CO emission rate of 2.6 g/hp-hr. Compliance with these federal limits is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit				Limit Units					
Upper		Lower		Code	Description				
2.6				319	Grams per horsepower hour				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
			14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	IIII	4205					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P03	BSG01-04	NY075 - 00 - 0		Particulates			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The proposed engines will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a particulate emission rate of 0.15 g/hp-hr. Compliance with these federal limits is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.15				319	Grams per brake horsepower hour				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
			14	As required		10	Upon request		



DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			☒ State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P03	BSG01-04	7664 - 09 - 05		Sulfur dioxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate ☒ Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
The facility will maintain a SO2 emission limit of 0.002 lb/MMBtu as BACT for the proposed project. In order to maintain this limit, the proposed engine will only combust ULSD diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 oil							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.0015				57	Percent by weight				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			☒ State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00001	EP001	P03	BSG01-04	7664 - 93 - 9		Sulfuric acid mist			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate ☒ Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
The facility will maintain an H2SO4 emission limit of 0.00003 lb/MMBtu as BACT for the proposed project. In order to maintain this limit, the proposed engine will only combust ULSD diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 oil							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.0015				57	Percent by weight				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	As required		10	Upon request		

New York State Department of Environmental Conservation
Air Permit Application

MODIFIED 

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Description										" Continuation Sheet(s)
EMISSION UNIT	U	-	0	0	0	0	0	2	This generating unit will fire natural gas exclusively and consist of one CTG, one HRSG with supplemental duct firing, and an associated ACC.	

Building					" Continuation Sheet(s)
Building	Building Name		Length (ft)	Width (ft)	Orientation
CTGEN01	Turbine Generation Building		670	100	0°
HRSG02	Heat Recovery Steam Generator Enclosure		128	160	90°
ACC02	Air Cooled Condenser		190	190	90°

Emission Point							" Continuation Sheet(s)
EMISSION PT.	E	P	0	0	2	No. 2 Combustion Turbine Generator / HRSG	
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
435	283	170	228	179	N/A	N/A	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
						N/A	
70.2	1,193,469					N/A	
EMISSION PT.							
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control								" Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.	
ID	Type				Code	Description		
CT002	C	12/2011	3/2015	N/A			General Electric 7FA.05	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	
2061	25	MMBtu/hr, HHV@ ISO conditions						
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.	
ID	Type				Code	Description		
DB002	C	12/2011	3/2015	N/A			HRSG, Duct Burner	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type		
	Code	Description		Code	Description	Code	Description	
379	25	MMBtu/hr, HHV@ ISO conditions						

DEC ID									
-									

Section IV - Emission Unit Information

EMISSION UNIT		Emission Source/Control (continuation)							
U	-	0	0	0	0	2			
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
DLN02	K	12/2011	3/2015	N/A	103	Dry Low NOx Burner	General Electric		
Design Capacity	Design Capacity Units			Waste Feed			Waste Type		
	Code	Description		Code	Description		Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
SCR02		12/2011	3/2015	N/A	033	Selective catalytic reduction	TBD		
Design Capacity	Design Capacity Units			Waste Feed			Waste Type		
	Code	Description		Code	Description		Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
oxc02		12/2011	3/2015	N/A	110	Catalytic oxidation	TBD		
Design Capacity	Design Capacity Units			Waste Feed			Waste Type		
	Code	Description		Code	Description		Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed			Waste Type		
	Code	Description		Code	Description		Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed			Waste Type		
	Code	Description		Code	Description		Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed			Waste Type		
	Code	Description		Code	Description		Code	Description	
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed			Waste Type		
	Code	Description		Code	Description		Code	Description	

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Process Information										" Continuation Sheet(s)										
EMISSION UNIT							U	-	0	0	0	0	2	PROCESS		P	0	4		
Description																				
Process P04 represents natural gas firing in the Unit #2 F-class combustion turbine with and without supplemental duct firing. Dry low-NOx combustion technology and selective catalytic reduction will be used to control emissions of NOx from the process. An oxidation catalyst will be used to control emissions of CO and VOC. The natural gas HHV is assumed to be 966 Btu per standard cubic foot. Please see Section 2.0 of the application for a more detailed process description.																				
Source Classification Code (SCC)			Total Thruput				Thruput Quantity Units													
			Quantity/Hr		Quantity/Yr		Code		Description											
2-01-002-01			2.76		24,135		0115		million cubic feet of natural gas											
" Confidential x Operating at Maximum Capacity " Activity with Insignificant Emissions			Operating Schedule						Building			Floor/Location								
			Hrs/Day			Days/Yr														
			24			365														
Emission Source/Control Identifier(s)																				
CT002		DLN02		SCR02		OXC02		DB002												
EMISSION UNIT							-							PROCESS						
Description																				
Source Classification Code (SCC)			Total Thruput				Thruput Quantity Units													
			Quantity/Hr		Quantity/Yr		Code		Description											
" Confidential " Operating at Maximum Capacity " Activity with Insignificant Emissions			Operating Schedule						Building			Floor/Location								
			Hrs/Day			Days/Yr														
Emission Source/Control Identifier(s)																				

New York State Department of Environmental Conservation
Air Permit Application

MODIFIED 

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements								" Continuation Sheet(s)	
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U-00002	EP002	P04		40	CFR	60	KKKK	4320					
U-00002	EP002	P04		40	CFR	60	KKKK	4330	a				
U-00002	EP002	P04		40	CFR	60	KKKK	4333	a				
U-00002	EP002	P04		40	CFR	60	KKKK	4340	b				

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements								" Continuation Sheet(s)	
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U-00002	EP002	P04		6	NYCRR	242	1	6					
U-00002	EP002	P04		6	NYCRR	242	1	7					
U-00002	EP002	P04		6	NYCRR	242	2						
U-00002	EP002	P04		6	NYCRR	242	3						

Emission Unit Compliance Certification										x Continuation Sheet(s)	
Rule Citation											
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause		
6	NYCRR	231	5	4							
x Applicable Federal Requirement				" State Only Requirement			" Capping				
Emission Unit	Emission Point	Process	Emission Source	CAS No.			Contaminant Name				
U-00002	EP002	P04		NY210 - 00 - 0			Oxides of nitrogen				
Monitoring Information											
x Continuous Emission Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate							
" Intermittent Emission Testing				" Work Practice Involving Specific Operations							
" Ambient Air Monitoring				" Record Keeping/Maintenance Procedures							
Description											
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (w/ and w/o duct burning) as LAER.											
This will be achieved through the application of DLN burners in combination with SCR. This limit applies at all load conditions except startup and shutdown. The facility will use CEMS to monitor NOx stack emissions.											
Work Practice		Process Material					Reference Test Method				
Type	Code	Description									
							40 CFR 60, Appendix A, Method 7E				
		Parameter					Manufacturer Name/Model No.				
Code	Description										
23	Concentration					DLN from General Electric, SCR is TBD					
Limit				Limit Units							
Upper	Lower	Code		Description							
2.0		275		parts per million by volume (dry, corrected to 15% O2)							
Averaging Method			Monitoring Frequency			Reporting Requirements					
Code	Description		Code	Description		Code	Description				
08	1-hour average		01	Continuous		07	Quarterly				

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U-00002	EP002	P04		40	CFR	60	KKKK	4345	a,b,c,d,e				
U-00002	EP002	P04		40	CFR	60	KKKK	4350					
U-00002	EP002	P04		40	CFR	60	KKKK	4365	a				
U-00002	EP002	P04		40	CFR	60	KKKK	4375	a				
U-00002	EP002	P04		40	CFR	60	KKKK	4380	b				
U-00002	EP002	P04		40	CFR	60	KKKK	4395					
U-00002	EP002	P04		40	CFR	60	KKKK	4400					
U-00002	EP002	P04		40	CFR	60	KKKK	4405					
U-00002	EP002	P04		6	NYCRR	227	2	4	e				
U-00002	EP002	P04		6	NYCRR	227	2	6	b				
U-00002	EP002	P04		6	NYCRR	243	1	6					
U-00002	EP002	P04		6	NYCRR	243	1	7					
U-00002	EP002	P04		6	NYCRR	243	2						
U-00002	EP002	P04		6	NYCRR	243	3						
U-00002	EP002	P04		6	NYCRR	243	4						
U-00002	EP002	P04		6	NYCRR	243	5						
U-00002	EP002	P04		6	NYCRR	243	6						
U-00002	EP002	P04		6	NYCRR	243	7						
U-00002	EP002	P04		6	NYCRR	243	8						
U-00002	EP002	P04		6	NYCRR	244	1	6					
U-00002	EP002	P04		6	NYCRR	244	1	7					
U-00002	EP002	P04		6	NYCRR	244	2						
U-00002	EP002	P04		6	NYCRR	244	3						
U-00002	EP002	P04		6	NYCRR	244	4						
U-00002	EP002	P04		6	NYCRR	244	5						
U-00002	EP002	P04		6	NYCRR	244	6						
U-00002	EP002	P04		6	NYCRR	244	7						
U-00002	EP002	P04		6	NYCRR	244	8						
U-00002	EP002	P04		6	NYCRR	245	1	6					
U-00002	EP002	P04		6	NYCRR	245	1	7					
U-00002	EP002	P04		6	NYCRR	245	2						
U-00002	EP002	P04		6	NYCRR	245	3						
U-00002	EP002	P04		6	NYCRR	245	4						
U-00002	EP002	P04		6	NYCRR	245	5						
U-00002	EP002	P04		6	NYCRR	245	6						
U-00002	EP002	P04		6	NYCRR	245	7						
U-00002	EP002	P04		6	NYCRR	245	8						
U-00002	EP002	P04		6	NYCRR	231	5	4					
U-00002	EP002	P04		6	NYCRR	231	7	6					
U-00002	EP002	P04		40	CFR	72	A	6	a	3			

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	227	2	4	e	2			
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00002	EP002	P04		NY210- 00 - 0		Oxides of nitrogen			
Monitoring Information									
X Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (with and without duct burning) as LAER for the proposed project. Meeting the LAER limit will also satisfy the requirements of 6NYCRR 227 2.4 as LAER is more stringent than the limit under this regulation.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						40 CFR 60, Appendix A, Method 7E			
		Parameter				Manufacturer Name/Model No.			
Code	Description				Manufacturer Name/Model No.				
23	Concentration				DLN from General Electric, SCR is TBD				
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0		275	Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		01	Continuous		07	Quarterly		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	KKKK	4345	a,b,c,d,e				
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U- 00002	EP002	P04		NY210- 00 - 0		Oxides of nitrogen			
Monitoring Information									
X Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (with and without duct burning) as LAER for the proposed project. Meeting the LAER limit will also satisfy the requirements of 40 CFR 60 Subpart KKKK as LAER is more stringent than the limit under this regulation.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						40 CFR 60, Appendix A, Method 7E			
		Parameter				Manufacturer Name/Model No.			
Code	Description				Manufacturer Name/Model No.				
23	Concentration				DLN from General Electric, SCR is TBD				
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0			Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		01	Continuous		07	Quarterly		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	5	4					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00002	EP002	P04		NY998 - 00 - 0		Volatile organic compounds			
Monitoring Information									
" Continuous Emission Monitoring ☒ Intermittent Emission Testing " Ambient Air Monitoring					" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures				
Description									
Facility will maintain a VOC emission limit of 1.0 ppmv at 15 percent O2 without duct burning and 2.0 ppmv with duct burning as LAER. These levels of emissions will be achieved via good combustion control and an oxidation catalyst. These emission limits apply at all load conditions except startup and shutdown. Stack testing will be used to demonstrate compliance with this limit.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 25A			
Parameter		Manufacturer Name/Model No.							
Code	Description								
23	Concentration								
Limit		Limit Units							
Upper	Lower	Code	Description						
1.0		275	Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				
08	1-hour average	14	As required	10	Upon request				
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				-					
Monitoring Information									
" Continuous Emission Monitoring ☒ Intermittent Emission Testing " Ambient Air Monitoring					" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures				
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
Parameter		Manufacturer Name/Model No.							
Code	Description								
Limit		Limit Units							
Upper	Lower	Code	Description						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00002	EP002	P04		630 - 08 - 0		Carbon monoxide			
Monitoring Information									
☒ Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a CO emission limit of 2.0 ppmv at 15 percent O2 with and without duct burning as BACT for the proposed project. This level of emissions will be achieved via good combustion control and an oxidation catalyst. The facility will use CEMS to monitor CO stack emissions.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						40 CFR 60, Appendix A, Method 10			
		Parameter				Manufacturer Name/Model No.			
Code		Description				Manufacturer Name/Model No.			
23		Concentration				TBD			
Limit		Limit Units							
Upper		Lower		Code	Description				
2.0				275	Parts per million by volume (dry, corrected to 15% O2)				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		01	Continuous		07	Quarterly		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00002	EP002	P04		NY075 - 00 - 0		Particulates			
Monitoring Information									
" Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
☒ Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a PM10/PM2.5 emission limit of 0.005 lb/MMBtu without duct burning and 0.006 lb/MMBtu with duct burning as BACT for the proposed project. These levels of emissions will be achieved by combusting only commercially available, pipeline quality natural gas in the turbines and duct burner. The facility will demonstrate compliance with these limits via stack testing.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						EPA RM5, 201/201A & 202			
		Parameter				Manufacturer Name/Model No.			
Code		Description				Manufacturer Name/Model No.			
23		Concentration							
Limit		Limit Units							
Upper		Lower		Code	Description				
0.006				7	pounds per million Btus				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	As required		10	Upon request		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				- -					
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit			Limit Units						
Upper	Lower	Code	Description						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
x Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00002	EP002	P04		7446 - 09 - 5		Sulfur dioxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate x Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by combusting commercially available, pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF in the combustion turbines.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	12	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit			Limit Units						
Upper	Lower	Code	Description						
0.5		13	grains per 100 DSCF						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum, not to be exceeded		14	As required		10	Upon request		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
x Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U - 00002	EP002	P04		7664 - 93 - 9		Sulfuric acid mist			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate x Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a sulfuric acid mist limit of 0.0004 lb/MMBtu without duct burning and 0.0006 lb/MMBtu with duct burning as BACT for the proposed project. These levels of emissions will be achieved by combusting commercially available, pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF in the combustion turbines.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.5				13	grains per 100 DSCF				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum, not to be exceeded		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				- -					
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit				Limit Units					
Upper		Lower		Code	Description				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Description										" Continuation Sheet(s)
EMISSION UNIT	U	-	0	0	0	0	0	3	This generating unit will fire natural gas exclusively and consist of one CTG, one HRSG with supplemental duct firing, and an associated ACC.	

Building					" Continuation Sheet(s)	
Building	Building Name			Length (ft)	Width (ft)	Orientation
CTGEN01	Turbine Generation Building			670	100	0°
HRSG03	Heat Recovery Steam Generator Enclosure			128	160	90°
ACC03	Air Cooled Condenser			190	190	90°

Emission Point							" Continuation Sheet(s)
EMISSION PT.	E	P	0	0	3	No. 3 Combustion Turbine Generator / HRSG	
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
435	283	170	228	179	N/A	N/A	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
70.2	1,193,469					N/A	
EMISSION PT.							
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control							" Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.
ID	Type				Code	Description	
CT003	C	12/2011	3/2015	N/A			General Electric 7FA.05
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
2061	25	MMBtu/hr, HHV@ ISO conditions					
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.
ID	Type				Code	Description	
DB003	C	12/2011	3/2015	N/A			HRSG, Duct Burner
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
379	25	MMBtu/hr, HHV@ ISO conditions					

DEC ID									
-									

Section IV - Emission Unit Information

EMISSION UNIT									
U	-	0	0	0	0	3	Emission Source/Control (continuation)		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
DLN03	K	12/2011	3/2015	N/A	103	Dry low NOx Burner	General Electric		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
SCR03		12/2011	3/2015	N/A	033	Selective catalytic reduction	TBD		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
oxc03		12/2011	3/2015	N/A	110	Catalytic oxidation	TBD		
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.		
ID	Type				Code	Description			
Design Capacity	Design Capacity Units			Waste Feed		Waste Type			
	Code	Description		Code	Description	Code	Description		

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Process Information										" Continuation Sheet(s)									
EMISSION UNIT							U	-	0	0	0	0	3	PROCESS		P	0	5	
Description																			
Process P05 represents natural gas firing in the F-class combustion turbine without supplemental duct firing. Dry low-NOx combustion technology and selective catalytic reduction will be used to control emissions of NOx from the process. An oxidation catalyst will be used to control emissions of CO and VOC. The natural gas HHV is assumed to be 966 Btu per standard cubic foot. Please see Section 2.0 of the application for a more detailed process description.																			
Source Classification Code (SCC)		Total Thruput			Thruput Quantity Units														
		Quantity/Hr	Quantity/Yr		Code			Description											
2-01-002-01		2.76	24,135		0115			million cubic feet of natural gas											
" Confidential x Operating at Maximum Capacity " Activity with Insignificant Emissions				Operating Schedule					Building		Floor/Location								
				Hrs/Day		Days/Yr													
				24		365													
Emission Source/Control Identifier(s)																			
CT003		DLN03		SCR03		OXC03		DB003											
EMISSION UNIT							-							PROCESS					
Description																			
Source Classification Code (SCC)		Total Thruput			Thruput Quantity Units														
		Quantity/Hr	Quantity/Yr		Code			Description											
" Confidential " Operating at Maximum Capacity " Activity with Insignificant Emissions				Operating Schedule					Building		Floor/Location								
				Hrs/Day		Days/Yr													
Emission Source/Control Identifier(s)																			

New York State Department of Environmental Conservation
Air Permit Application

MODIFIED 

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements								" Continuation Sheet(s)		
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause	
U-00003	EP003	P05		40	CFR	60	KKKK	4320						
U-00003	EP003	P05		40	CFR	60	KKKK	4330	a					
U-00003	EP003	P05		40	CFR	60	KKKK	4333	a					
U-00003	EP003	P05		40	CFR	60	KKKK	4340	b					

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements								" Continuation Sheet(s)		
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause	
U-00003	EP003	P05		6	NYCRR	242	1	6						
U-00003	EP003	P05		6	NYCRR	242	1	7						
U-00003	EP003	P05		6	NYCRR	242	2							
U-00003	EP003	P05		6	NYCRR	242	3							

Emission Unit Compliance Certification										x Continuation Sheet(s)	
Rule Citation											
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause		
6	NYCRR	231	5	4							
x Applicable Federal Requirement				" State Only Requirement			" Capping				
Emission Unit	Emission Point	Process	Emission Source	CAS No.			Contaminant Name				
U-00003	EP003	P05		NY210 - 00 - 0			Oxides of nitrogen				
Monitoring Information											
x Continuous Emission Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate							
" Intermittent Emission Testing				" Work Practice Involving Specific Operations							
" Ambient Air Monitoring				" Record Keeping/Maintenance Procedures							
Description											
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (w/ and w/o duct burning) as LAER.											
This will be achieved through the application of DLN burners in combination with SCR. This limit applies at all load conditions except startup and shutdown. The facility will use CEMS to monitor NOx stack emissions.											
Work Practice		Process Material					Reference Test Method				
Type	Code	Description									
							40 CFR 60, Appendix A, Method 7E				
		Parameter					Manufacturer Name/Model No.				
Code	Description										
23	Concentration					DLN from General Electric, SCR is TBD					
Limit				Limit Units							
Upper	Lower	Code		Description							
2.0		275		parts per million by volume (dry, corrected to 15% O2)							
Averaging Method			Monitoring Frequency			Reporting Requirements					
Code	Description		Code	Description		Code	Description				
08	1-hour average		01	Continuous		07	Quarterly				

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause
U-00003	EP003	P05		40	CFR	60	KKKK	4345	a,b,c,d,e				
U-00003	EP003	P05		40	CFR	60	KKKK	4350					
U-00003	EP003	P05		40	CFR	60	KKKK	4365	a				
U-00003	EP003	P05		40	CFR	60	KKKK	4375	a				
U-00003	EP003	P05		40	CFR	60	KKKK	4380	b				
U-00003	EP003	P05		40	CFR	60	KKKK	4395					
U-00003	EP003	P05		40	CFR	60	KKKK	4400					
U-00003	EP003	P05		40	CFR	60	KKKK	4405					
U-00003	EP003	P05		6	NYCRR	227	2	4	e				
U-00003	EP003	P05		6	NYCRR	227	2	6	b				
U-00003	EP003	P05		6	NYCRR	243	1	6					
U-00003	EP003	P05		6	NYCRR	243	1	7					
U-00003	EP003	P05		6	NYCRR	243	2						
U-00003	EP003	P05		6	NYCRR	243	3						
U-00003	EP003	P05		6	NYCRR	243	4						
U-00003	EP003	P05		6	NYCRR	243	5						
U-00003	EP003	P05		6	NYCRR	243	6						
U-00003	EP003	P05		6	NYCRR	243	7						
U-00003	EP003	P05		6	NYCRR	243	8						
U-00003	EP003	P05		6	NYCRR	244	1	6					
U-00003	EP003	P05		6	NYCRR	244	1	7					
U-00003	EP003	P05		6	NYCRR	244	2						
U-00003	EP003	P05		6	NYCRR	244	3						
U-00003	EP003	P05		6	NYCRR	244	4						
U-00003	EP003	P05		6	NYCRR	244	5						
U-00003	EP003	P05		6	NYCRR	244	6						
U-00003	EP003	P05		6	NYCRR	244	7						
U-00003	EP003	P05		6	NYCRR	244	8						
U-00003	EP003	P05		6	NYCRR	245	1	6					
U-00003	EP003	P05		6	NYCRR	245	1	7					
U-00003	EP003	P05		6	NYCRR	245	2						
U-00003	EP003	P05		6	NYCRR	245	3						
U-00003	EP003	P05		6	NYCRR	245	4						
U-00003	EP003	P05		6	NYCRR	245	5						
U-00003	EP003	P05		6	NYCRR	245	6						
U-00003	EP003	P05		6	NYCRR	245	7						
U-00003	EP003	P05		6	NYCRR	245	8						
U-00003	EP003	P05		6	NYCRR	231	5	4					
U-00003	EP003	P05		6	NYCRR	231	7	6					
U-00003	EP003	P05		40	CFR	72	A	6	a	3			

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	227	2	4	e	2			
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00003	EP003	P05		NY210- 00 - 0		Oxides of nitrogen			
Monitoring Information									
X Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (with and without duct burning) as LAER for the proposed project. Meeting the LAER limit will also satisfy the requirements of 6NYCRR 227 2.4 as LAER is more stringent than the limit under this regulation.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						40 CFR 60, Appendix A, Method 7E			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
23	Concentration				DLN is General Electric, SCR is TBD				
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0		275	Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		01	Continuous		07	Quarterly		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	KKKK	4345	a,b,c,d,e				
X Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U- 00003	EP003	P05		NY210- 00 - 0		Oxides of nitrogen			
Monitoring Information									
X Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (with and without duct burning) as LAER for the proposed project. Meeting the LAER limit will also satisfy the requirements of 40 CFR 60 Subpart KKKK as LAER is more stringent than the limit under this regulation.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				Reference Test Method			
						40 CFR 60, Appendix A, Method 7E			
Parameter		Manufacturer Name/Model No.							
Code	Description				Manufacturer Name/Model No.				
23	Concentration				DLN is General Electric, SCR is TBD				
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0			Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		01	Continuous		07	Quarterly		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	5	4					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00003	EP003	P05		NY998 - 00 - 0		Volatile organic compounds			
Monitoring Information									
" Continuous Emission Monitoring ☒ Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a VOC emission limit of 1.0 ppmv at 15 percent O2 without duct burning and 2.0 ppmv with duct burning as LAER. These levels of emissions will be achieved via good combustion control and an oxidation catalyst. These emission limits applies at all load conditions except startup and shutdown. Stack testing will be used to demonstrate compliance with these limits.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 25A			
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit		Limit Units							
Upper		Lower		Code	Description				
1.0				275	Parts per million by volume (dry, corrected to 15% O2)				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
08	1-hour average		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				-					
Monitoring Information									
" Continuous Emission Monitoring ☒ Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit		Limit Units							
Upper		Lower		Code	Description				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00003	EP003	P05		630 - 08 - 0		Carbon monoxide			
Monitoring Information									
☒ Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
" Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a CO emission limit of 2.0 ppmv at 15 percent O2 with and without duct burning as BACT for the proposed project. This level of emissions will be achieved via good combustion control and an oxidation catalyst. The facility will use CEMS to monitor CO stack emissions.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				40 CFR 60, Appendix A, Method 10			
Parameter		Manufacturer Name/Model No.							
Code	Description	TBD							
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
2.0		275	Parts per million by volume (dry, corrected to 15% O2)						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				
08	1-hour average	01	Continuous	07	Quarterly				
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00003	EP003	P05		NY075 - 00 - 0		Particulates			
Monitoring Information									
" Continuous Emission Monitoring			" Monitoring of Process or Control Device Parameters as Surrogate						
☒ Intermittent Emission Testing			" Work Practice Involving Specific Operations						
" Ambient Air Monitoring			" Record Keeping/Maintenance Procedures						
Description									
Facility will maintain a PM10/PM2.5 emission limit of 0.005 lb/MMBtu without duct burning and 0.006 lb/MMBtu with duct burning as BACT for the proposed project. These levels of emissions will be achieved by combusting only commercially available, pipeline quality natural gas in the turbines and duct burner. The facility will demonstrate compliance with these limits via stack testing.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description				EPA RM5, 201/201A & 202			
Parameter		Manufacturer Name/Model No.							
Code	Description	TBD							
23	Concentration								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.006		7	pounds per million Btus						
Averaging Method		Monitoring Frequency		Reporting Requirements					
Code	Description	Code	Description	Code	Description				
08	1-hour average	14	As required	10	Upon request				

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				- -					
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code	Description								
Limit			Limit Units						
Upper	Lower	Code	Description						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
x Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00003	EP003	P05		7446 - 09 - 5		Sulfur dioxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate x Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by combusting commercially available, pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF in the combustion turbines.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	12	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code	Description								
32	Sulfur content								
Limit			Limit Units						
Upper	Lower	Code	Description						
0.5		13	grains per 100 DSCF						
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum, not to be exceeded		14	As required		10	Upon request		

DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
x Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U - 00003	EP003	P05		7664 - 93 - 9		Sulfuric acid mist			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate x Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Facility will maintain a sulfuric acid mist limit of 0.0004 lb/MMBtu without duct burning and 0.0006 with duct burning as BACT for the proposed project. These levels of emissions will be achieved by combusting commercially available, pipeline quality natural gas with a maximum sulfur content of 0.5 grains/100 SCF in the combustion turbines.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	012	Natural gas							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.5				13	grains per 100 DSCF				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum, not to be exceeded		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				-					
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit				Limit Units					
Upper		Lower		Code	Description				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		



DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Description										" Continuation Sheet(s)
EMISSION UNIT	U	-	0	0	0	0	4	This emission unit represents the emergency fire pump at the facility. The fire pump will operate for a maximum of 500 hours per year.		

Building					" Continuation Sheet(s)	
Building	Building Name			Length (ft)	Width (ft)	Orientation
WATANK	Service/fire water storage tank					

Emission Point							" Continuation Sheet(s)
EMISSION PT.	E	P	0	0	4	Emergency Fire Pump	
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
435	50	0	8	787			
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	
120	2528						
EMISSION PT.							
Ground Elev. (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (EF)	Cross Section		
					Length (in)	Width (in)	
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal	

Emission Source/Control							" Continuation Sheet(s)
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.
ID	Type				Code	Description	
FP01	C	12/2011	3/2015	N/A			TBD
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description
460	220	Horsepower					
Emission Source		Date of Construction	Date of Operation	Date of Removal	Control Type		Manufacturer's Name/Model No.
ID	Type				Code	Description	
Design Capacity	Design Capacity Units			Waste Feed		Waste Type	
	Code	Description		Code	Description	Code	Description

New York State Department of Environmental Conservation
Air Permit Application



DEC ID									
-									

Section IV - Emission Unit Information (continued)

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements								x Continuation Sheet(s)		
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause	
U-00004	EP004	P06	EP001	40	CFR	60	IIII	4202						
U-00004	EP004	P06	EP001	40	CFR	60	IIII	4205						
U-00004	EP004	P06	EP001	40	CFR	60	IIII	4207						
U-00004	EP004	P06	EP001	40	CFR	60	IIII	4209	a					

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements								" Continuation Sheet(s)		
				Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause	
-														
-														
-														
-														

Emission Unit Compliance Certification										x Continuation Sheet(s)		
Rule Citation												
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause			
40	CFR	60	IIII	4205								
x Applicable Federal Requirement				" State Only Requirement			" Capping					
Emission Unit	Emission Point	Process	Emission Source	CAS No.			Contaminant Name					
U-00004	EP004	P06	FP01	NY210 - 00 - 0			Oxides of nitrogen					
Monitoring Information												
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations x Record Keeping/Maintenance Procedures								
Description												
The proposed engine will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a NOx + HC emission rate of 3.0 g/hp-hr. Compliance with these federal limits is also considered LAER. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.												
Work Practice		Process Material					Reference Test Method					
Type	Code	Description										
		Parameter					Manufacturer Name/Model No.					
Code	Description											
23	Concentration											
Limit				Limit Units								
Upper	Lower	Code		Description								
3.0		319		Grams per brake horsepower hour								
Averaging Method			Monitoring Frequency				Reporting Requirements					
Code	Description		Code	Description			Code	Description				
			14	As required			10	Upon request				



DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	IIII	4205					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00004	EP004	P06	FP01	NY998 - 00 - 0		Volatile organic compounds			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The proposed engine will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a NOx + HC emission rate of 3.0 g/hp-hr. Compliance with these federal limits is also considered LAER. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit				Limit Units					
Upper		Lower		Code	Description				
3.0				319	Grams per brake horsepower hour				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
			14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	IIII	4205					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00004	EP004	P06	FP01	630 - 08 - 0		Carbon monoxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The proposed engine will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a CO emission rate of 2.6 g/hp-hr. Compliance with these federal limits is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit				Limit Units					
Upper		Lower		Code	Description				
2.6				319	Grams per brake horsepower hour				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
			14	As required		10	Upon request		

New York State Department of Environmental Conservation
Air Permit Application



DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
40	CFR	60	IIII	4205					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00004	EP004	P06	FP01	NY075-00-0		Particulates			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations ☒ Record Keeping/Maintenance Procedures					
Description									
The proposed engines will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engines will maintain a particulate emission rate of 0.15 g/hp-hr. Compliance with these federal limits is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
23		Concentration							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.15				319	Grams per brake horsepower hour				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
			14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00004	EP004	P06	FP01	7664-04-05		Sulfur dioxide			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate ☒ Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
The facility will maintain a SO2 emission limit of 0.002 lb/MMBtu as BACT for the proposed project. In order to maintain this limit, the proposed engine will only combust ULSD diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 oil							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit				Limit Units					
Upper		Lower		Code	Description				
0.0015				57	Percent by weight				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	As required		10	Upon request		



DEC ID									
-									

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)									
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
6	NYCRR	231	7	6					
☒ Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
U-00004	EP004	P06	FP01	7664 - 93 - 9		Sulfuric acid mist			
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate ☒ Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
The facility will maintain an H2SO4 emission limit of 0.00003 lb/MMBtu as BACT for the proposed project. In order to maintain this limit, the proposed engine will only combust ULSD diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight.									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
04	007	Number 2 oil							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
32		Sulfur content							
Limit			Limit Units						
Upper		Lower		Code	Description				
0.0015				57	Percent by weight				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		
01	Maximum not to be exceeded		14	As required		10	Upon request		
Rule Citation									
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause
" Applicable Federal Requirement			" State Only Requirement			" Capping			
Emission Unit	Emission Point	Process	Emission Source	CAS No.		Contaminant Name			
-				-					
Monitoring Information									
" Continuous Emission Monitoring " Intermittent Emission Testing " Ambient Air Monitoring				" Monitoring of Process or Control Device Parameters as Surrogate " Work Practice Involving Specific Operations " Record Keeping/Maintenance Procedures					
Description									
Work Practice		Process Material				Reference Test Method			
Type	Code	Description							
		Parameter				Manufacturer Name/Model No.			
Code		Description							
Limit			Limit Units						
Upper		Lower		Code	Description				
Averaging Method			Monitoring Frequency			Reporting Requirements			
Code	Description		Code	Description		Code	Description		

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Determination of Non-Applicability (Title V Only)							" Continuation Sheet(s)			
Rule Citation										
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause	
Emission Unit		Emission Point		Process		Emission Source		" Applicable Federal Requirement " State Only Requirement		
Description										
Rule Citation										
Title	Type	Part	Sub Part	Section	Sub Division	Paragraph	Sub Paragraph	Clause	Sub Clause	
Emission Unit		Emission Point		Process		Emission Source		" Applicable Federal Requirement " State Only Requirement		
Description										
Process Emissions Summary							" Continuation Sheet(s)			
EMISSION UNIT		-					PROCESS		-	-
CAS No.	Contaminant Name				% Thruput	% Capture	% Control	ERP (lbs/hr)	ERP How Determined	
-	-									
PTE			Standard Units		PTE How Determined		Actual			
(lbs/hr)	(lbs/yr)	(standard units)					(lbs/hr)	(lbs/yr)		
EMISSION UNIT		-					PROCESS		-	-
CAS No.	Contaminant Name				% Thruput	% Capture	% Control	ERP (lbs/hr)	ERP How Determined	
-	-									
PTE			Standard Units		PTE How Determined		Actual			
(lbs/hr)	(lbs/yr)	(standard units)					(lbs/hr)	(lbs/yr)		
EMISSION UNIT		-					PROCESS		-	-
CAS No.	Contaminant Name				% Thruput	% Capture	% Control	ERP (lbs/hr)	ERP How Determined	
-	-									
PTE			Standard Units		PTE How Determined		Actual			
(lbs/hr)	(lbs/yr)	(standard units)					(lbs/hr)	(lbs/yr)		

DEC ID									
-									

Section IV - Emission Unit Information (continued)

EMISSION UNIT		Emission Unit Emissions Summary				" Continuation Sheet(s)	
-							
CAS No.		Contaminant Name					
- -							
ERP (lbs/yr)	PTE Emissions		Actual				
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)			
CAS No.		Contaminant Name					
- -							
ERP (lbs/yr)	PTE Emissions		Actual				
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)			
CAS No.		Contaminant Name					
- -							
ERP (lbs/yr)	PTE Emissions		Actual				
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)			
CAS No.		Contaminant Name					
- -							
ERP (lbs/yr)	PTE Emissions		Actual				
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)			

Compliance Plan												" Continuation Sheet(s)	
For any emission units which are <u>not in compliance</u> at the time of permit application, the applicant shall complete the following													
Consent Order			Certified progress reports are to be submitted every 6 months beginning ____ / ____ / ____										
Emission Unit	Process	Emission Source	Applicable Federal Requirement										
			Title	Type	Part	Sub Part	Section	Sub Division	Parag.	Sub Parag.	Clause	Sub Clause	
-													
Remedial Measure / Intermediate Milestones										R/I		Date Scheduled	

DEC ID									
-									

Section IV - Emission Unit Information (continued)

Request for Emission Reduction Credits										" Continuation Sheet(s)									
EMISSION UNIT		-								Emission Reduction Description									
Contaminant Emission Reduction Data																			
Baseline Period ____ / ____ / ____ to ____ / ____ / ____										Reduction									
										Date					Method				
										____ / ____ / ____									
CAS No.					Contaminant Name					ERC (lbs/yr)									
										Netting					Offset				
-					-														
-					-														
-					-														
Facility to Use Future Reduction																			
Name										APPLICATION ID									
										- / - / - / - / - / - / - / - / - / -									
Location Address																			
" City / " Town / " Village										State					Zip				

Use of Emission Reduction Credits										" Continuation Sheet(s)									
EMISSION UNIT		-								Proposed Project Description									
Contaminant Emissions Increase Data																			
CAS No.					Contaminant Name					PEP (lbs/yr)									
-					-														
Statement of Compliance																			
" All facilities under the ownership of this "ownership/firm" are operating in compliance with all applicable requirements and state regulations including any compliance certification requirements under Section 114(a)(3) of the Clean Air Act Amendments of 1990, or are meeting the schedule of a consent order.																			
Source of Emission Reduction Credit - Facility																			
Name										PERMIT ID									
										- / - / - / - / - / - / - / - / - / -									
Location Address																			
" City / " Town / " Village										State					Zip				
Emission Unit		CAS No.			Contaminant Name					ERC (lbs/yr)									
										Netting					Offset				
-		-																	
-		-																	
-		-																	

DEC ID									
-									

Supporting Documentation

- ✕ P.E. Certification (form attached)
- " List of Exempt Activities (form attached)
- ✕ Plot Plan
- " Methods Used to Determine Compliance (form attached)
- ✕ Calculations
- " Air Quality Model (____ / ____ / ____)
- " Confidentiality Justification
- " Ambient Air Monitoring Plan (____ / ____ / ____)
- " Stack Test Protocols/Reports (____ / ____ / ____)
- " Continuous Emissions Monitoring Plans/QA/QC (____ / ____ / ____)
- " MACT Demonstration (____ / ____ / ____)
- " Operational Flexibility: Description of Alternative Operating Scenarios and Protocols
- " Title IV: Application/Registration
- " ERC Quantification (form attached)
- " Use of ERC(s) (form attached)
- " Baseline Period Demonstration
- " Analysis of Contemporaneous Emission Increase/Decrease
- ✕ LAER Demonstration (____ / ____ / ____)
- ✕ BACT Demonstration (____ / ____ / ____)
- " Other Document(s): _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)
 _____ (____ / ____ / ____)

ARCADIS

ATTACHMENT 3

Attachment 3

Additional Supporting Documentation for Air Permit Application

List of Contents

Vendor information

- fire pump
- black start generators
- auxiliary boiler

Supporting Calculations for Modeling Results (provided on diskette)

- Steady state
- Startup/Shutdown plus Auxiliary Boiler
- Auxiliary Boiler
- Black Start Generator
- Fire Pump

Supporting Figures for Modeling Results

- Land use Figures for AERSURFACE
- Windroses
- 1-hour Carbon Monoxide (CO)
- 8-hour CO
- 1-hour NO₂
- Annual NO₂
- 24-hour Particulate Matter less than 2.5 microns (PM_{2.5})
- Annual PM_{2.5}
- 24-hour Particulate Matter less than 10 microns (PM₁₀)
- 1-hour SO₂
- 3-hour SO₂
- 24-hour SO₂
- Annual SO₂

Tier 3 Emissions Data - John Deere Power Systems

Nameplate Rating Information

Clarke Model	JX6H-UFADF0
Power Rating (BHP / kW)	460 / 343
Certified Speed (RPM)	1760

Certificate Data

John Deere Engine Rating	6135HFC48B
Engine Model Year *	2009
EPA Family Name	9JDXL13.5103
EPA Certificate Number	JDX-NRCI-09-24
CARB Executive Order Number	U-R-004-0370
Emissions Label Part Number	R528979

* The Engine Model Year is listed on the emissions label.

Emissions Data **

Units	g/hp-hr	g/kW-hr
CO	0.53	0.71
Pm	0.087	0.116
NOx	2.6	3.48
HC	0.097	0.13
NOx + HC	2.69	3.61
Test Engine	RG6135X000770	

** The emission data listed is measured from the calibration engine under laboratory test conditions. It is intended to represent an "average" engine but is not a guarantee that all engines meet these values.



John Deere Power Systems
3801 W. Ridgeway Ave., PO Box 5100
Waterloo, Iowa USA 50704-5100

Scope of Supply

MIRATECH Corporation Scope of Supply

	Model Number	Quantity per Engine
Selective Catalytic Reduction Housing	CBL81-30	1
SCR Housing	CBL81-30	1
SCR Catalyst	RFV.0890.40.0150.450	81
SCR Control System	Dosing System	1
SE Dosing System	SE75.lab.ops	1
SE Injector	DES75.600	1
Temperature Switch	TS	1
Over Temperature Sensor	TEB600	1
Mixing Section Components	30" Mixing Section (2 Mixer).we	1
Pre-Fabricated Mixing Section	30" Mixing Section (2 Mixer).we	1
Flow Dresser	30" Flow Dresser	1
Dosing Mixer	30" Dosing Mixer	1
Static Mixer	30" Static Mixer	1
Mixing Section Injector Flange	30" Mixing Section Injector Flange	1
SCR Reactant Tank	SW1500.ht.ins	(optional)
Level Transmitter	LU20	1 (optional)
Level Controller	LI55	1 (optional)
Level Controller Enclosure	LM92	1 (optional)
Reactant Tank	SW1500.ht.ins	1 (optional)
Spare Parts	Dosing System Recommended Spare Parts	(optional)
Recommended Spare Parts	SE75 Recommended Spare Parts	1 (optional)
Maintenance Pack	Dosing System Maintenance Pack	(optional)
Maintenance Pack	DEX75.XXX Maintenance Pack	1 (optional)
	SE75 Maintenance Pack	1 (optional)

Customer Scope of Supply

Description
Support Structure
Attachment to Support Structure (Bolts, Nuts, Levels, etc.)
Expansion Joints
Exhaust Piping
Inlet Pipe Bolts, Nuts, & Gasket
Outlet Pipe Bolts, Nuts, & Gasket
Insulation for Exhaust Piping
Power Input (230 VAC, 60 Hz, Single Phase)
Component Installation Including External Tubing and Wiring
Isolated Engine Load Signal to MIRATECH Equipment (4-20 mA)
Dry Contact (N.O.) for Engine Run Signal to MIRATECH Equipment
Heat Tracing of Reactant Lines (Required when Ambient Temperatures are Below 40 °F)
Design for Structural Support and Thermal Expansion

Application Data

Project Information

Site Location: NY
 Project Name: Advanced Power
 Application: Standby Power
 Number of Engines: 1
 Operating Hours per Year: 200

Engine Specifications

Engine Manufacturer: Caterpillar
 Model Number: C175-16
 Operating Load for Engine Data Provided: 100%
 Power Output: 4,376 bhp
 Speed: 1,800 RPM
 Type of Fuel: Number 2 Diesel
 Sulfur Content: 500 ppmv or less
 Fuel Consumption: 6,314 BTU/bhp-hr
 Type of Lube Oil: 1.0 wt% sulfated ash or less
 Lube Oil Consumption: < 0.00027 gal/bhp-hr
 Exhaust Flow Rate: 24,300 acfm (cfm)
 Exhaust Temperature: 883°F

Raw Engine Emission Data

	g/bhp-hr	lb/MW-hr	ppmvd	ppmvd @ 15% O ₂	lb/hr	g/kW-hr	tons/yr
NO _x	6.22	18.39	1,001	597	60.01	8.34	6.00
CO	1.17	3.46	309	184	11.29	1.57	1.13
PM ₁₀	0.05	0.15	30.86	18.39	0.48	0.07	0.05

% O₂ 11.0
 H₂O Assumption 12.5

System Specifications and Performance Warranty Data

SCR System Specifications (CBL81-30, Dosing System, 30" Mixing Section (2 Mixer).we)

Design Exhaust Flow Rate:	24,300 acfm (cfm)
Design Exhaust Temperature ¹ :	883°F
Total Catalyst Volume:	29 cubic feet
SCR Catalyst Volume:	29 cubic feet
SCR Catalyst Space Velocity:	19,464 1/hr
System Pressure Loss:	5.0 inches of WC (Fresh)
Sound Attenuation:	25-30 dBA insertion loss
Reactant:	Urea
Percent Concentration:	32.5%
System Dosing Capacity:	75 L/hr
Estimated Reactant Consumption:	11 gal/hr (41 L/hr) / Per Engine

Post System Emission Data

	g/bhp-hr	lb/MW-hr	ppmvd	ppmvd @ 15% O ₂	lb/hr	g/kW-hr	tons/yr
NO _x	2.13	6.30	343	204	20.55	2.86	2.05
CO	2.60	7.69	688	410	25.08	3.49	2.51
PM ₁₀	0.15	0.44	93	55	1.45	0.20	0.14

Calculated Percent Reductions

	% Reduction
NO _x	65.8
CO	0.0
PM ₁₀	0.0

Equipment Details

Selective Catalytic Reduction Housing Details (CBL81-30)

SCR Housing Details	CBL81-30 SD
• Model Number:	CBL81-30
• Quantity ² :	1
• Number of Catalyst Layers:	1.0
• Number of Spare Catalyst Layers:	1.0
• Number of Catalyst Blocks per Layer:	81
• Material:	Carbon Steel
• Paint:	None
• Inlet Pipe Size & Connection:	30 inch FF Flange, 150# ANSI standard bolt pattern
• Outlet Pipe Size & Connection:	30 inch FF Flange, 150# ANSI standard bolt pattern
• Dimensions:	62.750" H x 61.125" W x 119" L
• Weight Without Catalyst:	2,166 lbs
• Weight Fully Loaded With Catalyst:	5,594 lbs
SCR Catalyst Details	
• Model Number:	RFV.0890.40.0150.450
• Quantity ² :	81
• Catalyst Optimum Temperature Range ³ :	752 – 887°F
• Catalyst Dimensions:	5.91" W x 5.91" H x 17.72" L

Mixing Section Components Details (30" Mixing Section (2 Mixer).we)

Pre-Fabricated Mixing Section Details	30" Mixing Section (2 mixer).we SD
• Model Number:	30" Mixing Section (2 Mixer).we
• Quantity ² :	1
• Material:	304 SS
• Overall Length:	156 inches
• Weight:	852 lbs
Flow Dresser Details	
• Model Number:	30" Flow Dresser
• Quantity ² :	1
• Weight:	87 lbs
Dosing Mixer Details	
• Model Number:	30" Dosing Mixer
• Quantity ² :	1
• Weight:	34 lbs
Static Mixer Details	
• Model Number:	30" Static Mixer
• Quantity ² :	1
• Weight:	40 lbs
Mixing Section Injector Flange Details	
• Model Number:	30" Mixing Section Injector Flange
• Quantity ² :	1
• Weight:	4 lbs

SCR Control System Details (Dosing System)

SE Dosing System Details	SE75 SD
• Model Number:	SE75.lab.ops
• Quantity ² :	1
• Overall Dimensions:	26.339 W x 58.99 H x 14.568 D
• Weight:	331 lbs

Equipment Details (continued)

SCR Control System Details (Dosing System) (continued)

SE Injector Details

- Model Number: DES75.600
- Quantity²: 1
- Weight: 19 lbs

Temperature Switch Details

- Model Number: TS
- Quantity²: 1
- Weight: 2 lbs

Over Temperature Sensor Details

- Model Number: TEB600
- Quantity²: 1
- Weight: 3 lbs

Maintenance Pack Details (Dosing System Maintenance Pack)

Maintenance Pack Details

- Model Number: DEX75.XXX Maintenance Pack
- Quantity²: 1

Maintenance Pack Details

- Model Number: SE75 Maintenance Pack
- Quantity²: 1

Spare Parts Details (Dosing System Recommended Spare Parts)

Recommended Spare Parts Details

- Model Number: SE75 Recommended Spare Parts
- Quantity²: 1

SCR Reactant Tank Details (SW1500.ht.ins)

Level Transmitter Details

- Model Number: LU20
- Quantity²: 1

Level Controller Details

- Model Number: LI55
- Quantity²: 1

Level Controller Enclosure Details


- Model Number: LM92
- Quantity²: 1

Reactant Tank Details

- Model Number: SW1500 SD
SW1500.ht.ins
- Quantity²: 1
- Tank Dimensions: 66.5 D x 121 H
- Weight: 415 lbs





Special Notes/Conditions

- 1 Carbon steel housings are suitable for use in all applications where the housing will not be insulated. Carbon steel housings may only be insulated in applications where the exhaust temperature does not exceed 900°F. If your application requires insulation with an engine exhaust temperature exceeding 900°F, a stainless steel housing is required. Customer installed insulation on carbon steel housings in applications where exhaust temperature exceeds 900°F voids any MIRATECH product warranty.
 - 2 Quantities are per engine.
 - 3 SCR units require a minimum temperature of 572°F (300°C) and a maximum temperature of 986°F (530°C). Several catalyst formulations are available with different optimum operating temperatures. The optimum operating temperature for this application is listed. Operating outside of the optimum range will change the reactant consumption and could cause damage to the catalyst.
- MIRATECH does not allow any silencer, packed or unpacked, to be installed upstream of any MIRATECH equipment. Installation of such equipment will void the warranty per MIRATECH Holdings Terms and Conditions.
 - Final catalyst housings are dependent on engine output and required emission reductions. Changes may be made to optimize the system design at the time of order.
 - Any drawings included with this proposal are preliminary in nature and could change depending on final product selection.



		CBL SE System Overview Drawing	
		DRAWING	REV 5
DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED	DO NOT SCALE DRAWING	DRAWN JCU	DATE 9/25/2009
PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.	REVIEWED BY JWS	DATE 9/25/2009	SIZE A NOT TO SCALE
SIZE A	NOT TO SCALE	CBL-SE SOD	SHEET 1 OF 1

WEIGHTS (APPROXIMATE)	
EMPTY HOUSING	2166 lb
ONE (1) FULL SCR CATALYST LAYER	1703 lb
TWO (2) FULL SCR CATALYST LAYERS	3428 lb
<ul style="list-style-type: none"> HOUSING HAS CAPACITY FOR TWO (2) FULL SCR CATALYST LAYERS 	



NOTES:

- ONLY USE LIFTING LUGS TO LIFT HOUSING
- ALLOW MINIMUM 28\"/>

MATERIAL CONSTRUCTION:

- CARBON STEEL

PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.



DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED	
DO NOT SCALE DRAWING	
DRAWN JCU	DATE 9/25/2009
REVIEWED BY JWS	DATE 9/25/2009

PROJECT NAME	
SALES ORDER NO.	
FABRICATION P.O.	



CBL81-30 Sales Drawing

DRAWING	CBL81-30 SD	REV	1
SIZE	A	SCALE	1/4\"/>
			SHEET 1 OF 1



30" Mixing Section (2 Mixer)-we Sales Drawing

DRAWING: 30 Mixing Section (2 Mixer)-we SD
REV: 5

SITE: A
SCALE: 1:50
WEIGHT: 852 lb

SHEET 1 OF 1

DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED


DO NOT SCALE DRAWING

DRAWN	AJM	DATE	1/5/2010
REVIEWED BY	JWS	DATE	1/5/2010

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.

PROJECT NAME	
SALES ORDER NO.	
FABRICATION P.O.	



MIRATECH CORPORATION

**SE75 Controller
Sales Drawing**


DRAWING	SE75 SD	REV	5	SHEET 1 OF 1
SITE		SCALE	WEIGHT	
A		1/28	331 lb	

DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED			
DO NOT SCALE DRAWING	DRAWN	DATE	DATE
	JCU	9/25/2009	9/25/2009
REVIEWED BY	JWS		


PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.

PROJECT NAME	
SALES ORDER NO.	
FABRICATION P.O.	


- NOTES:**
- POWER CONSUMPTION: 1300 W
 - VOLTAGE: 230 VAC +/- 10%, SINGLE ϕ , 60 HZ
 - CURRENT DRAW: 6.0 A
 - OPERATION TEMPERATURE: 32°F - 104°F
 - NO DEW DROPS ALLOWED
- INSTALLATION INSTRUCTIONS:**
- IF UNIT IS INSTALLED IN AN ENCLOSURE, THE ENCLOSURE MUST BE VENTILATED AND TEMPERATURE CONTROLLED TO MAINTAIN PROPER OPERATION TEMPERATURE.
 - UNIT MAY BE FLOOR OR WALL MOUNTED AND ACCESSIBLE WHILE ENGINE IS IN OPERATION




RIGHT VIEW



TOP VIEW



FRONT VIEW



SW1500 Reactant Tank Sales Drawing

DRAWING: SW1500 SD
 REV: 5
 SCALE: 1/60
 SITE: A
 WEIGHT: 415lb EMPTY
 SHEET 1 OF 1

DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED	
DO NOT SCALE DRAWING	
DRAWN: JJG	DATE: 9/25/2009
REVIEWED BY: JWS	DATE: 9/25/2009

PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED.

PROJECT NAME	
SALES ORDER NO.	
FABRICATION P.O.	

- NOTES:**
- CAPACITY: 1450 (US GALLONS)
 - (OPTIONAL) SEISMIC TIE DOWNS ARE RATED UBC ZONE 4
 - MATERIAL CONSTRUCTION: CROSSLINK POLYETHYLENE



January 28, 2011

Advanced Power (NA)
31 Milk Street, Suite 1001
Boston, MA 02109

Attention: Mr. Jeff Ahrens

RE: Cricket Valley Energy - Power Plant Aux Boiler Burners - Emissions

Ms. Ahrens:

In follow up to your request for design conditions and emission guarantees on the boiler for the Cricket Valley Energy Project I am pleased to offer the following for your review. I have provided thermal data on the boiler at the varying temperature conditions. In addition, please also see the letter from Coen Burner Company addressing Emission guarantees for our boiler.

Once you have had a chance to review the information I have provided please do not hesitate to contact me should you have any questions or require further assistance.

Very truly yours,

VICTORY ENERGY OPERATIONS, LLC

A handwritten signature in black ink that reads "Dianna Jarvis". The signature is written in a cursive, flowing style.

Dianna Jarvis
Sales Associate
Ph: 918-382-4885
Fax: 918-274-0059
Email: djarvis@victoryenergy.com



Advanced Energy (NA)

January 28, 2011

Page 2

VICTORY ENERGY CUSTOMER SPEC SHEET

Customer: Cricket Valley Energy

Date: 8/24/2010

Reference: VS-4-45

Quote Number: VE-4301 REV1

SAT,NG Ambient Temperature =59F

=====

PREDICTED PERFORMANCE

LOAD		DESIGN	LOAD 1	LOAD 2	LOAD 3
Outlet Steam Flow,	(lbs/hr)	50000	37500	25000	12500
Fuel/Firing Conditions -					
Fuel Fired		Natural Gas	Natural Gas	Natural Gas	Natural Gas
Excess Air,	(%)	15.00	15.00	15.00	15.00
Flue Gas Recirc.,	(%)	30.00	30.00	30.00	30.00
Steam/Water Conditions -					
Steam Temp @ NRV Outlet	(deg F)	435.8	435.8	435.7	435.7
Steam Pres @ NRV Outlet	(psig)	350.0	350.0	350.0	350.0
Boiler Saturation Temp.	(deg F)	438.3	437.1	436.3	435.8
Boiler Operating Press.	(psig)	360.0	355.6	352.5	350.6
Econ. Water Exit Temp,	(deg F)	351.1	337.4	322.9	310.7
Feedwater Inlet Temp,	(deg F)	227.0	227.0	227.0	227.0
Flow Quantities -					
Percent Blowdown,	(%)	1.00	1.00	1.00	1.00
Blowdown Flow,	(lbs/hr)	505	379	253	126
Feedwater Flow,	(lbs/hr)	50,505	37,879	25,253	12,626
Fuel Flow,	(lbs/hr)	2,692	2,012	1,344	689
Combustion Air Flow,	(lbs/hr)	50,975	38,111	25,452	13,052
Flue Gas Flow LVG System,(lbs/hr)		53,666	40,123	26,796	13,741
Flue Gas Recirc. Flow,	(lbs/hr)	16,100	12,037	8,039	4,122
Flue Gas Flow w/Recirc.,	(lbs/hr)	69,766	52,161	34,835	17,863
Air/Gas Temperatures -					
Ambient Air Temp.,	(deg F)	59.0	59.0	59.0	59.0
Comb. Air/FGR Mixture,	(deg F)	120.1	114.3	109.1	104.7
Adiabatic Flame Temp,	(deg F)	3,297.3	3,294.3	3,291.7	3,289.5
Flame Temp w/ Recirc.,	(deg F)	2,688.8	2,681.5	2,675.0	2,669.5
Effec. Furnace Gas Temp,	(deg F)	2,169	2,049	1,881	1,606
Furnace Exit Gas Temp,	(deg F)	2,088	1,957	1,773	1,472
Boiler Exit Gas Temp,	(deg F)	636	578	519	463
Gas Temp. LVG Economizer,	(deg F)	300	277	257	240
Flue Gas Recirc. Temp.	(deg F)	300	277	257	240
System Efficiency -					
Dry Gas Losses,	(%)	4.53	4.11	3.72	3.40
Water From Fuel Fired,	(%)	10.90	10.80	10.71	10.63
Moisture in Air Losses,	(%)	0.06	0.05	0.05	0.04
Radiation Loss,	(%)	0.67	0.94	1.57	4.05
Manufactures Margin,	(%)	1.00	1.00	1.00	1.00
Total Heat Losses,	(%)	17.16	16.90	17.05	19.12
Boiler Efficiency,	(%)	82.84	83.10	82.95	80.88
HHV Heat Input By Fuel,(mmbtu/hr)		61.016	45.618	30.466	15.623



Advanced Energy (NA)

January 28, 2011

Page 3

System Draft Losses -

Fan Inlet:

Silencer,	(inwc)	1.50	0.89	0.42	0.12
Fan Inlet Ducts,	(inwc)	0.50	0.30	0.14	0.04

Fan Outlet:

Fan Outlet Ducts,	(inwc)	0.50	0.30	0.14	0.04
Burner,	(inwc)	7.00	4.13	1.95	0.55
Convection Zone,	(inwc)	4.11	2.26	0.99	0.25
Economizer,	(inwc)	0.81	0.44	0.19	0.05
Outlet Gas Ducts,	(inwc)	0.50	0.30	0.14	0.04
Total Draft Losses,	(inwc)	14.91	8.60	3.98	1.08

Furnace Performance -

Heat Available,	(mmbtu/hr)	54.367	40.693	27.204	13.962
Heat Absorbed in Furn,	(mmbtu/hr)	13.265	11.997	9.877	6.378
Liberation Rate,	(btu/hr-ft ³)	75792	56666	37844	19406
Furnace Release Rate,	(btu/hr-ft ²)	96228	71930	48030	24626
Residence Time,	(sec)	0.669	0.938	1.505	3.326

Convection Zone Performance -

Gas Mass Velocity	(lb/hr-ft ²)	5,241	3,918	2,617	1,342
Gas Velocity at Inlet,	(ft/sec)	97.32	69.01	42.58	18.89
Heat Absorbed in Conv.,	(mmbtu/hr)	31.36	22.02	13.18	5.31

Economizer Performance -

Gas Mass Velocity	(lb/hr-ft ²)	5,547	4,147	2,769	1,420
Gas Velocity at Inlet	(ft/sec)	44.29	31.37	19.75	9.55
Water Flow Through Econ,	(lb/hr)	50,505	37,879	25,253	12,626
Water Mass Velocity,	(lb/sec-ft ²)	215.86	161.89	107.93	53.96
Feedwater Pressure Drop,	(psi)	5.09	2.88	1.30	0.34
Heat Absorbed in Econ.,	(mmbtu/hr)	6.42	4.28	2.47	1.08



Advanced Energy (NA)

January 28, 2011

Page 4

VICTORY ENERGY CUSTOMER SPEC SHEET

Customer: Cricket Valley Energy

Date: 8/24/2010

Reference: VS-4-45

Quote Number: VE-4301 REV1

SAT,NG Ambient Temperature =105F

PREDICTED PERFORMANCE

LOAD		DESIGN	LOAD 1	LOAD 2	LOAD 3
Outlet Steam Flow,	(lbs/hr)	50000	37500	25000	12500
Fuel/Firing Conditions -					
Fuel Fired		Natural Gas	Natural Gas	Natural Gas	Natural Gas
Excess Air,	(%)	15.00	15.00	15.00	15.00
Flue Gas Recirc.,	(%)	30.00	30.00	30.00	30.00
Steam/Water Conditions -					
Steam Temp @ NRV Outlet	(deg F)	435.8	435.8	435.7	435.7
Steam Pres @ NRV Outlet	(psig)	350.0	350.0	350.0	350.0
Boiler Saturation Temp.	(deg F)	438.3	437.1	436.3	435.8
Boiler Operating Press.	(psig)	360.0	355.6	352.5	350.6
Econ. Water Exit Temp,	(deg F)	353.7	339.9	325.4	313.0
Feedwater Inlet Temp,	(deg F)	227.0	227.0	227.0	227.0
Flow Quantities -					
Percent Blowdown,	(%)	1.00	1.00	1.00	1.00
Blowdown Flow,	(lbs/hr)	505	379	253	126
Feedwater Flow,	(lbs/hr)	50,505	37,879	25,253	12,626
Fuel Flow,	(lbs/hr)	2,659	1,987	1,326	680
Combustion Air Flow,	(lbs/hr)	51,810	38,719	25,846	13,244
Flue Gas Flow LVG System,(lbs/hr)		54,469	40,706	27,173	13,923
Flue Gas Recirc. Flow,	(lbs/hr)	16,341	12,212	8,152	4,177
Flue Gas Flow w/Recirc.,	(lbs/hr)	70,809	52,918	35,324	18,100
Air/Gas Temperatures -					
Ambient Air Temp.,	(deg F)	105.0	105.0	105.0	105.0
Comb. Air/FGR Mixture,	(deg F)	155.8	149.8	144.4	139.7
Adiabatic Flame Temp,	(deg F)	3,192.8	3,189.8	3,187.2	3,184.9
Flame Temp w/ Recirc.,	(deg F)	2,605.9	2,598.5	2,591.7	2,585.9
Effec. Furnace Gas Temp,	(deg F)	2,118	2,003	1,840	1,572
Furnace Exit Gas Temp,	(deg F)	2,042	1,915	1,737	1,444
Boiler Exit Gas Temp,	(deg F)	634	577	518	463
Gas Temp. LVG Economizer,	(deg F)	302	279	258	240
Flue Gas Recirc. Temp.	(deg F)	302	279	258	240
System Efficiency -					
Dry Gas Losses,	(%)	3.71	3.28	2.88	2.54
Water From Fuel Fired,	(%)	10.48	10.38	10.28	10.20
Moisture in Air Losses,	(%)	0.26	0.23	0.20	0.18
Radiation Loss,	(%)	0.67	0.94	1.57	4.05
Manufactures Margin,	(%)	1.00	1.00	1.00	1.00
Total Heat Losses,	(%)	16.12	15.83	15.94	17.98
Boiler Efficiency,	(%)	83.88	84.17	84.06	82.02
HHV Heat Input By Fuel,(mmbtu/hr)		60.264	45.037	30.064	15.405



System Draft Losses -

Fan Inlet:

Silencer,	(inwc)	1.50	0.88	0.42	0.12
Fan Inlet Ducts,	(inwc)	0.50	0.29	0.14	0.04

Fan Outlet:

Fan Outlet Ducts,	(inwc)	0.50	0.29	0.14	0.04
Burner,	(inwc)	7.00	4.13	1.95	0.54
Convection Zone,	(inwc)	4.22	2.33	1.02	0.26
Economizer,	(inwc)	0.84	0.46	0.20	0.05
Outlet Gas Ducts,	(inwc)	0.50	0.29	0.14	0.04
Total Draft Losses,	(inwc)	15.06	8.68	4.00	1.09

Furnace Performance -

Heat Available,	(mmbtu/hr)	53.950	40.365	26.973	13.833
Heat Absorbed in Furn,	(mmbtu/hr)	13.093	11.850	9.779	6.333
Liberation Rate,	(btu/hr-ft ³)	74858	55944	37344	19135
Furnace Release Rate,	(btu/hr-ft ²)	95294	71198	47516	24342
Residence Time,	(sec)	0.663	0.928	1.489	3.289

Convection Zone Performance -

Gas Mass Velocity	(lb/hr-ft ²)	5,319	3,975	2,654	1,360
Gas Velocity at Inlet,	(ft/sec)	98.38	69.80	43.09	19.14
Heat Absorbed in Conv.,	(mmbtu/hr)	31.40	22.06	13.21	5.32

Economizer Performance -

Gas Mass Velocity	(lb/hr-ft ²)	5,630	4,207	2,808	1,439
Gas Velocity at Inlet	(ft/sec)	45.54	32.26	20.31	9.81
Water Flow Through Econ,	(lb/hr)	50,505	37,879	25,253	12,626
Water Mass Velocity,	(lb/sec-ft ²)	215.86	161.89	107.93	53.96
Feedwater Pressure Drop,	(psi)	5.09	2.88	1.30	0.34
Heat Absorbed in Econ.,	(mmbtu/hr)	6.56	4.38	2.54	1.11



Advanced Energy (NA)

January 28, 2011

Page 5

VICTORY ENERGY CUSTOMER SPEC SHEET

Customer: Cricket Valley Energy

Date: 8/24/2010

Reference: VS-4-45

Quote Number: VE-4301 REV1 SAT,NG

Ambient Temperature =-8F

=====

PREDICTED PERFORMANCE

LOAD		DESIGN	LOAD 1	LOAD 2	LOAD 3
Outlet Steam Flow,	(lbs/hr)	50000	37500	25000	12500
Fuel/Firing Conditions -					
Fuel Fired		Natural Gas	Natural Gas	Natural Gas	Natural Gas
Excess Air,	(%)	15.00	15.00	15.00	15.00
Flue Gas Recirc.,	(%)	30.00	30.00	30.00	30.00
Steam/Water Conditions -					
Steam Temp @ NRV Outlet	(deg F)	435.8	435.8	435.7	435.7
Steam Pres @ NRV Outlet	(psig)	350.0	350.0	350.0	350.0
Boiler Saturation Temp.	(deg F)	438.3	437.1	436.3	435.8
Boiler Operating Press.	(psig)	360.0	355.6	352.5	350.6
Econ. Water Exit Temp,	(deg F)	352.5	338.6	323.9	311.5
Feedwater Inlet Temp,	(deg F)	227.0	227.0	227.0	227.0
Flow Quantities -					
Percent Blowdown,	(%)	1.00	1.00	1.00	1.00
Blowdown Flow,	(lbs/hr)	505	379	253	126
Feedwater Flow,	(lbs/hr)	50,505	37,879	25,253	12,626
Fuel Flow,	(lbs/hr)	2,741	2,049	1,368	702
Combustion Air Flow,	(lbs/hr)	51,577	38,559	25,751	13,211
Flue Gas Flow LVG System,(lbs/hr)		54,318	40,608	27,120	13,913
Flue Gas Recirc. Flow,	(lbs/hr)	16,295	12,182	8,136	4,174
Flue Gas Flow w/Recirc.,	(lbs/hr)	70,614	52,790	35,256	18,087
Air/Gas Temperatures -					
Ambient Air Temp.,	(deg F)	-8.0	-8.0	-8.0	-8.0
Comb. Air/FGR Mixture,	(deg F)	70.0	64.1	58.9	54.4
Adiabatic Flame Temp,	(deg F)	3,287.1	3,284.1	3,281.5	3,279.3
Flame Temp w/ Recirc.,	(deg F)	2,684.0	2,676.6	2,670.1	2,664.5
Effec. Furnace Gas Temp,	(deg F)	2,174	2,054	1,886	1,612
Furnace Exit Gas Temp,	(deg F)	2,094	1,963	1,779	1,479
Boiler Exit Gas Temp,	(deg F)	638	580	520	463
Gas Temp. LVG Economizer,	(deg F)	301	278	257	240
Flue Gas Recirc. Temp.	(deg F)	301	278	257	240
System Efficiency -					
Dry Gas Losses,	(%)	5.81	5.38	4.99	4.66
Water From Fuel Fired,	(%)	11.16	11.05	10.96	10.88
Moisture in Air Losses,	(%)	0.00	0.00	0.00	0.00
Radiation Loss,	(%)	0.67	0.94	1.57	4.05
Manufactures Margin,	(%)	1.00	1.00	1.00	1.00
Total Heat Losses,	(%)	18.64	18.39	18.53	20.60
Boiler Efficiency,	(%)	81.36	81.61	81.47	79.40
HHV Heat Input By Fuel,(mmbtu/hr)		62.131	46.448	31.020	15.914



Advanced Energy (NA)

January 28, 2011

Page 6

System Draft Losses -

Fan Inlet:

Silencer,	(inwc)	1.50	0.89	0.42	0.12
Fan Inlet Ducts,	(inwc)	0.50	0.30	0.14	0.04

Fan Outlet:

Fan Outlet Ducts,	(inwc)	0.50	0.30	0.14	0.04
Burner,	(inwc)	7.00	4.13	1.96	0.55
Convection Zone,	(inwc)	4.20	2.31	1.01	0.26
Economizer,	(inwc)	0.82	0.45	0.20	0.05
Outlet Gas Ducts,	(inwc)	0.50	0.30	0.14	0.04
Total Draft Losses,	(inwc)	15.02	8.66	4.00	1.09

Furnace Performance -

Heat Available,	(mmbtu/hr)	55.199	41.314	27.620	14.182
Heat Absorbed in Furn,	(mmbtu/hr)	12.883	11.712	9.695	6.291
Liberation Rate,	(btu/hr-ft ³)	77177	57696	38532	19768
Furnace Release Rate,	(btu/hr-ft ²)	98070	73301	48947	25107
Residence Time,	(sec)	0.662	0.928	1.489	3.287

Convection Zone Performance -

Gas Mass Velocity	(lb/hr-ft ²)	5,305	3,966	2,648	1,359
Gas Velocity at Inlet,	(ft/sec)	98.38	69.78	43.07	19.13
Heat Absorbed in Conv.,	(mmbtu/hr)	31.67	22.25	13.33	5.38

Economizer Performance -

Gas Mass Velocity	(lb/hr-ft ²)	5,614	4,197	2,803	1,438
Gas Velocity at Inlet	(ft/sec)	44.79	31.71	19.95	9.64
Water Flow Through Econ,	(lb/hr)	50,505	37,879	25,253	12,626
Water Mass Velocity,	(lb/sec-ft ²)	215.86	161.89	107.93	53.96
Feedwater Pressure Drop,	(psi)	5.09	2.88	1.30	0.34
Heat Absorbed in Econ.,	(mmbtu/hr)	6.50	4.33	2.50	1.09

Advanced Energy (NA)

January 28, 2011

Page 7



TODD®

January 26, 2011

Victory Energy Operations LLC
10701 East 126th Street, North
Collinsville OK 74021

Att: Dianna Jarvis, Sales Associate

Subject: TODD ultra low NOx RMB Burner Performance for VEO 50,000 lb/hr saturated boiler for Crickett Valley Energy

Dear Dianna:

Coen Company Inc. is pleased to confirm emission guarantees when using a TODD ultra low NOx RMB burner mounted on a Victory Energy Operations LLC boiler designed for a nominal 50,000 lb/hr saturated steam. When operating the boiler with an economizer, the RMB burner will operate at approximately 62 mmbtu/hr at 100% boiler load when firing natural gas. The RMB burner will operate at a nominal 15% excess air and 30% flue gas recirculation at 100% boiler load. Emissions are guaranteed from twenty-five (25) to one hundred (100) percent of boiler load, as follows:



- Maximum emission levels on natural gas, with all concentrations corrected to 3% oxygen, on a dry basis, with high heating value of 1,000 Btu/scf and sulfur content of 0.2 grains/100 scf of fuel:

NOx	9 ppm (0.011 lb/mmbtu)
CO	50 ppm (0.0375 lb/mmbtu)
VOC	3 ppm (0.0015 lb/mmbtu)
PM/PM10/PM2.5	0.005 lb/mmbtu
SOx	0.0006 lb/mmbtu

Yours truly,

Paul Schwartz
Director Industrial Steam
Coen Company Inc.

C:\Projects\PP_Misc\20091102_Dutchess\Cricket.mxd - 11/3/2009 @ 9:48:45 AM



PROJECT LOCATION

- Legend - NLCD 1992**
- Open Water
 - Perennial Ice/Snow
 - Low Intensity Residential
 - High Intensity Residential
 - Commercial/Industrial/Transportation
 - Bare Rock/Sand/Clay
 - Quarries/Strip Mines/Gravel Pits
 - Transitional
 - Deciduous Forest
 - Evergreen Forest
 - Mixed Forest
 - Shrubland
 - Orchards/Vineyards/Other
 - Grasslands/Herbaceous
 - Pasture/Hay
 - Row Crops
 - Small Grains
 - Fallow
 - Urban/Recreational Grasses
 - Woody Wetlands
 - Emergent Herbaceous Wetlands

41.6762 N, 73.5806 W

Meters






Cricket Valley

Land Use / Land Cover

CO001447.0003

C:\Projects\PP_Misc\20091102_Dutchess\KPOU.mxd - 11/2/2009 @ 5:03:46 PM




PROJECT LOCATION

Legend

- Open Water
- Perennial Ice/Snow
- Developed, Open Space
- Developed, Low Intensity
- Developed, Medium Intensity
- Developed, High Intensity
- Barren Land (Rock/Sand/Clay)
- Deciduous Forest
- Evergreen Forest
- Mixed Forest
- Shrub/Scrub
- Grassland/Herbaceous
- Pasture/Hay
- Cultivated Crops
- Woody Wetlands
- Emergent Herbaceous Wetlands

41.626 N, 73.882 W



**Poughkeepsie Dutchess
County Airport**

**Land Use /
Land Cover**


CO001447.0003

WIND ROSE PLOT:

Wind Rose for March 10, 2005 - March 9, 2006
Poughkeepsie Dutchess County Airport (KPOU)

DISPLAY:

Wind Speed
Direction (blowing from)



COMMENTS:

Winds Derived from 1-minute ASOS Data

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS



CALM WINDS:

14.63%

TOTAL COUNT:

8333 hrs.

AVG. WIND SPEED:

5.43 Knots

DATE:

2/1/2011


PROJECT NO.:

WIND ROSE PLOT:

Wind Rose for March 10, 2006 - March 9, 2007
Poughkeepsie Dutchess County Airport (KPOU)

DISPLAY:

Wind Speed
Direction (blowing from)



COMMENTS:

Winds Derived from 1-minute ASOS Data

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS



CALM WINDS:

8.82%

TOTAL COUNT:

8571 hrs.

AVG. WIND SPEED:

5.63 Knots

DATE:

2/1/2011


PROJECT NO.:

WIND ROSE PLOT:

**Wind Rose for March 10, 2007 - March 9, 2008
Poughkeepsie Dutchess County Airport (KPOU)**

DISPLAY:

**Wind Speed
Direction (blowing from)**



COMMENTS:

Winds Derived from 1-minute ASOS Data

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS



CALM WINDS:

1.12%

TOTAL COUNT:

8491 hrs.

AVG. WIND SPEED:

4.77 Knots

DATE:

2/1/2011


PROJECT NO.:

WIND ROSE PLOT:

**Wind Rose for March 10, 2008 - March 9, 2009
Poughkeepsie Dutchess County Airport (KPOU)**

DISPLAY:

**Wind Speed
Direction (blowing from)**



COMMENTS:

Winds Derived from 1-minute ASOS Data

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS



CALM WINDS:

1.10%

TOTAL COUNT:

8432 hrs.

AVG. WIND SPEED:

5.02 Knots

DATE:

2/1/2011


PROJECT NO.:

WIND ROSE PLOT:

**Wind Rose for March 10, 2009 - March 9, 2010
Poughkeepsie Dutchess County Airport (KPOU)**

DISPLAY:

**Wind Speed
Direction (blowing from)**



COMMENTS:

Winds Derived from 1-minute ASOS Data

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS



CALM WINDS:

5.39%

TOTAL COUNT:

8408 hrs.

AVG. WIND SPEED:

4.66 Knots


DATE:

2/1/2011

PROJECT NO.:


PROJECT TITLE:

**Highest 1-Hour Average CO - Cold Start plus Auxiliary Boiler
Cricket Valley Energy Project**



PLOT FILE OF HIGH 1ST HIGH 1-HR VALUES FOR SOURCE GROUP: ALL

ug/m³



COMMENTS:

2006

Emission Rate 89.1 g/s

SIL = 2000 ug/m³

SOURCES:

1

RECEPTORS:

1737

OUTPUT TYPE:

Concentration

MAX:

1483.55414 ug/m³

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS

SCALE:

1:92,373

0 3 km

DATE:


2/1/2011

PROJECT NO.:




PROJECT TITLE:

**Highest 8-Hour Average CO - Cold Start plus Auxiiary Boiler
Cricket Valley Energy Project**



PLOT FILE OF HIGH 1ST HIGH 3-HR VALUES FOR SOURCE GROUP: ALL

ug/m³



COMMENTS:

2007

Maximum 8-hour impact based on 3-hour average

Emission Rate 89.1 g/s for 2.4 hours (26.87 g/s after adjustment)

SIL = 500 ug/m³

SOURCES:

1

RECEPTORS:

1737

OUTPUT TYPE:

Concentration

MAX:

342.56575 ug/m³

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS

SCALE:

1:92,373



DATE:


2/1/2011



PROJECT NO.:

PROJECT TITLE:

**Predicted Five-Year Average Maximum 1-Hour NO2 Impact
Cricket Valley Energy - Cold Start plus Auxiliary Boiler**



PLOT FILE OF 1ST-HIGHEST MAX DAILY 1-HR VALUES AVERAGED OVER 5 YEARS FOR SOURCE GROUP: ALL ug/m³



COMMENTS:

Significant Impact Level 7.5 ug/m³ (4 ppb)

SOURCES:

1

COMPANY NAME:

Cricket Valley Energy Center, LLC

RECEPTORS:

3251

MODELER:

ARCADIS

OUTPUT TYPE:

Concentration

SCALE:

1:352,517

0

10 km



MAX:

68.57208 ug/m³


DATE:

1/28/2011

PROJECT NO.:

PROJECT TITLE:

**Predicted Annual NO2 - Maximum Annual Average
Cricket Valley Energy - 100% Load with DB, 59 F, 2008**



PLOT FILE OF PERIOD VALUES FOR SOURCE GROUP: COMB

ug/m³



COMMENTS:

Combined stacks.
Emission Rate: 7.068 g/s
SL: 1.0 ug/m³

SOURCES:

1

RECEPTORS:

1701

OUTPUT TYPE:
Concentration

MAX:
0.60991 ug/m³

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS

SCALE: 1:100,000




DATE:
1/30/2011



PROJECT NO.:


PROJECT TITLE:

**Cricket Valley Energy
Maximum 5-Year Average 24-Hour Impact for PM-2.5**



PLOT FILE OF HIGH 1ST HIGH 24-HR VALUES FOR SOURCE GROUP: COMB

ug/m³



COMMENTS:

SOURCES:

2

COMPANY NAME:

Cricket Valley Energy Center, LLC

RECEPTORS:

1737

MODELER:

ARCADIS

OUTPUT TYPE:

Concentration

SCALE:

1:112,165

0

4 km



MAX:

3.38385 ug/m³


DATE:

10/8/2010

PROJECT NO.:


PROJECT TITLE:

**PM-2.5 Annual 5-year average
3 Turbines Combined at 49% Load, 59F**



PLOT FILE OF PERIOD VALUES FOR SOURCE GROUP: COMB

ug/m³




COMMENTS: Emission rate 3.66 g/s SIL = 0.30 ug/m ³	SOURCES: 1	COMPANY NAME: Cricket Valley Energy Center, LLC
	RECEPTORS: 1701	MODELER: ARCADIS
	OUTPUT TYPE: Concentration	SCALE: 1:101,564 0  4 km
	MAX: 0.29775 ug/m³	DATE: 1/30/2011



PROJECT TITLE:

**Predicted 1-Hour SO₂ - Five-Year Average Maximum
Cricket Valley Energy - 100% Load with DB, 59 F**




PLOT FILE OF 1ST-HIGHEST MAX DAILY 1-HR VALUES AVERAGED OVER 5 YEARS FOR SOURCE GROUP: COMB ug/m³



COMMENTS:	SOURCES: 2	COMPANY NAME Cricket Valley Energy Center, LLC	
	RECEPTORS: 1737	MODELER: ARCADIS	
	OUTPUT TYPE: Concentration	SCALE: 1:90,374 0  3 km	
	MAX: 6.29191 ug/m³	DATE: 1/25/2011	PROJECT NO.:

PROJECT TITLE:

**Predicted Maximum 3-Hour Average SO₂
Cricket Valley Energy - 100% Load with DB, 59 F, 2005**



PLOT FILE OF HIGH 1ST HIGH 3-HR VALUES FOR SOURCE GROUP: COMB

ug/m³



COMMENTS:

Combined stacks.
Emission Rate: 1.344 g/s
SL: 25 ug/m³

SOURCES:

1

RECEPTORS:

1701

OUTPUT TYPE:

Concentration

MAX:

4.06172 ug/m³

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS

SCALE:

1:100,000



DATE:


1/30/2011



PROJECT NO.:

PROJECT TITLE:

**Predicted Maximum 24-hour Average SO2
Cricket Valley Energy - 100% Load with DB, 59 F, 2008**



PLOT FILE OF HIGH 8TH HIGH 24-HR VALUES FOR SOURCE GROUP: COMB

ug/m³



COMMENTS:

Combined stacks.
Emission Rate: 1.344 g/s
SL: 5.0 ug/m³

SOURCES:

1

RECEPTORS:

1701

OUTPUT TYPE:

Concentration

MAX:

0.48581 ug/m³

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS

SCALE:

1:100,000



DATE:


1/30/2011



PROJECT NO.:


PROJECT TITLE:

**Predicted Maximum Annual Average SO2
Cricket Valley Energy - 100% Load with DB, 59 F, 2008**



PLOT FILE OF PERIOD VALUES FOR SOURCE GROUP: COMB

ug/m³



COMMENTS:

Combined stacks.
Emission Rate: 1.344 g/s
SL: 1.0 ug/m³

SOURCES:

1

RECEPTORS:

1701

OUTPUT TYPE:

Concentration

MAX:

0.09696 ug/m³

COMPANY NAME:

Cricket Valley Energy Center, LLC

MODELER:

ARCADIS

SCALE:

1:100,000



DATE:

1/30/2011



PROJECT NO.: